



HISTORIC PRESERVATION COMMISSION

Marc Elrich
County Executive

Robert Sutton
Chairman

Date: October 26, 2023

MEMORANDUM

TO: Rabbiah Sabbakhan
Department of Permitting Services

FROM: Michael Kyne
Historic Preservation Section
Maryland-National Capital Park & Planning Commission

SUBJECT: Historic Area Work Permit #1043533: Solar panel installation.

The Montgomery County Historic Preservation Commission (HPC) has reviewed the attached application for a Historic Area Work Permit (HAWP). This application was **Approved** at the October 25, 2023 HPC meeting.

The HPC staff has reviewed and stamped the attached construction drawings.

THE BUILDING PERMIT FOR THIS PROJECT SHALL BE ISSUED CONDITIONAL UPON ADHERENCE TO THE ABOVE APPROVED HAWP CONDITIONS AND MAY REQUIRE APPROVAL BY DPS OR ANOTHER LOCAL OFFICE BEFORE WORK CAN BEGIN.

Applicant: Jeffrey Luker (Fusion Solar Service, Agent)
Address: 7307 Takoma Avenue, Takoma Park

This HAWP approval is subject to the general condition that the applicant will obtain all other applicable Montgomery County or local government agency permits. After the issuance of these permits, the applicant must contact this Historic Preservation Office if any changes to the approved plan are made. Once work is complete the applicant will contact Michael Kyne at 301.563.3403 or michael.kyne@montgomeryplanning.org to schedule a follow-up site visit.





FOR STAFF ONLY:
HAWP# 1043533
DATE ASSIGNED

APPLICATION FOR HISTORIC AREA WORK PERMIT
HISTORIC PRESERVATION COMMISSION
301.563.3400

APPLICANT:

Name: Address: Daytime Phone: E-mail: City: Zip: Tax Account No.:

AGENT/CONTACT (if applicable):

Name: Address: Daytime Phone: E-mail: City: Zip: Contractor Registration No.:

LOCATION OF BUILDING/PREMISE: MIHP # of Historic Property

Is the Property Located within an Historic District? Yes/District or No/Individual
Is there an Historic Preservation/Land Trust/Environmental Easement or Historic District Map of the Property?

REVIEWED By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
Montgomery County
Historic Preservation Commission
[Signature]

Are other Planning and/or Hearing Examiner Approvals /Review (Conditional Use, Variance, Record Plat, etc.?) If YES, include info supplemental information.

Building Number: Street: Town/City: Nearest Cross Street: Lot: Block: Subdivision: Parcel:

TYPE OF WORK PROPOSED: See the checklist on Page 4 to verify that all supporting items for proposed work are submitted with this application. Incomplete Applications will not be accepted for review. Check all that apply:

- New Construction, Addition, Demolition, Grading/Excavation, Deck/Porch, Fence, Hardscape/Landscape, Roof, Shed/Garage/Accessory Structure, Solar, Tree removal/planting, Window/Door, Other:

I hereby certify that I have the authority to make the foregoing application, that the application is correct and accurate and that the construction will comply with plans reviewed and approved by all necessary agencies and hereby acknowledge and accept this to be a condition for the issuance of this permit.

Ola Carew

Signature of owner or authorized agent

Date

HAWP APPLICATION: MAILING ADDRESSES FOR NOTIFYING
[Owner, Owner's Agent, Adjacent and Confronting Property Owners]

| | |
|---|---|
| Owner's mailing address | Owner's Agent's mailing address |
| Adjacent and confronting Property Owners mailing addresses | |
| 7305 Baltimore Avenue, Takoma Park 20912 | 7310 Piney Branch Road, Takoma Park 20912 |
| | |

REVIEWED
By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
Montgomery County
Historic Preservation Commission



Description of Property: Please describe the building and surrounding environment. Include information on significant structures, landscape features, or other significant features of the property:

Description of Work Proposed: Please give an overview of the work to be undertaken:

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED

Montgomery County

Historic Preservation Commission




Robert G. Patton

| | |
|-----------------------------------|----------------|
| Work Item 1: _____ | |
| Description of Current Condition: | Proposed Work: |

| | |
|-----------------------------------|----------------|
| Work Item 2: _____ | |
| Description of Current Condition: | Proposed Work: |

REVIEWED
By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
Montgomery County
Historic Preservation Commission



| | |
|-----------------------------------|----------------|
| Work Item 3: _____ | |
| Description of Current Condition: | Proposed Work: |

**HISTORIC AREA WORK PERMIT
CHECKLIST OF
APPLICATION REQUIREMENTS**

| | Required Attachments | | | | | | |
|--------------------------------|------------------------|--------------|---------------------|----------------------------|----------------|----------------|-----------------------------|
| Proposed Work | I. Written Description | 2. Site Plan | 3. Plans/Elevations | 4. Material Specifications | 5. Photographs | 6. Tree Survey | 7. Property Owner Addresses |
| New Construction | * | * | * | * | * | * | * |
| Additions/Alterations | * | * | * | * | * | * | * |
| Demolition | * | * | * | | * | | * |
| Deck/Porch | * | * | * | * | * | * | * |
| Fence/Wall | * | * | * | * | * | * | * |
| Driveway/Parking Area | * | * | | * | * | * | * |
| Grading/Excavation/Landscaping | * | * | | * | * | * | * |
| Tree Removal | * | * | | * | * | * | * |
| Siding/ Roof Changes | * | * | * | * | * | | * |
| Window/Door Changes | * | * | * | * | * | | * |
| Masonry Repair/Repoint | * | * | * | * | * | | * |
| Signs | * | * | * | * | * | | * |

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED

Montgomery County

Historic Preservation Commission

Fwd: FW: Solar Installation at 7307 Takoma Ave, Takoma Park MD

1 message

Steven Coffman <scoffman@luminasolar.com>
To: Olajumoke Carew <ocarew@luminasolar.com>

Wed, Sep 20, 2023 at 2:48 PM

Luker email confirmation from neighbors



Steve Coffman

Project Manager

301.509.4376

luminasolar.com

3600 Commerce Dr., Ste 601
Baltimore, MD 21227

Leave us a Review!

- Google - Lumina Solar
- SolarReviews - Lumina Solar
- Facebook - Lumina Solar
- Energysage - Lumina Solar
- Home Advisor - Lumina Solar

----- Forwarded message -----

From: **Jeffrey Luker** <jeffrey.luker@quinnevans.com>
Date: Wed, Sep 20, 2023 at 2:41 PM
Subject: FW: Solar Installation at 7307 Takoma Ave, Takoma Park MD
To: scoffman@luminasolar.com <scoffman@luminasolar.com>

Hi Steve,

Here is 1 of 2 approvals.

Jeffrey Luker, AIA, LEED AP

Principal



REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

202 591 2509 direct

202 744 7494 mobile



From: Richard Henrich <rhenrich@erols.com>
Sent: Wednesday, September 20, 2023 2:29 PM
To: Jeffrey Luker <jeffrey.luker@quinnevans.com>
Cc: 'Steven Coffman' <scoffman@luminasolar.com>
Subject: Solar Installation at 7307 Takoma Ave, Takoma Park MD

Hi Jeff:

I am writing to confirm that I enthusiastically approve your project for the installation of solar panels on your home!

Best regards and congratulations,

Richard Henrich
7305 Takoma Ave
Takoma Park, MD 20912
202-441-0832

2 attachments




image001.png
9K

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

image001.png
9K



Fwd: FW: Interconnection Approved! ALSO Historic application

Steven Coffman <scoffman@luminasolar.com>
To: Olajumoke Carew <ocarew@luminasolar.com>

Wed, Sep 20, 2023 at 2:48 PM

Luker email confirmation from neighbors



Steve Coffman
Project Manager
301.509.4376
luminasolar.com

3600 Commerce Dr., Ste 601
Baltimore, MD 21227

Leave us a Review!

- Google - Lumina Solar
- SolarReviews - Lumina Solar
- Facebook - Lumina Solar
- Energysage - Lumina Solar
- Home Advisor - Lumina Solar

----- Forwarded message -----

From: **Jeffrey Luker** <jeffrey.luker@quinnevans.com>
Date: Wed, Sep 20, 2023 at 2:41 PM
Subject: FW: Interconnection Approved! ALSO Historic application
To: scoffman@luminasolar.com <scoffman@luminasolar.com>

Hi Steve,

Here is 2 of 2 approvals,


Jeffrey Luker, AIA, LEED AP

REVIEWED
Principal
By Michael Kyne at 4:50 pm, Oct 26, 2023



202 591 2509 direct

202 744 7494 mobile



From: Jay Dintaman <jaydavmex8@gmail.com>
Sent: Wednesday, September 20, 2023 2:07 PM
To: Jeffrey Luker <jeffrey.luker@quinnevans.com>
Subject: Re: Interconnection Approved! ALSO Historic application

Jeff,

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

We have no objections to your proposal to install solar panels on your roof.

Jay Dintaman

7309 Takoma Ave

Sent from my iPhone



On Sep 20, 2023, at 1:53 PM, Jeffrey Luker <jeffrey.luker@quinnevans.com> wrote:

Richard and Jay,

As discussed, we are planning to replace and add solar panels to our roof. Here is an image of the panel layout:

<image002.jpg>

To include with our application to the Montgomery County Historic Commission we need statement from you stating that you have no objections to the proposed work.

If you are are willing, will you please send me a brief email confirming approval. Or let me know if you have any concerns.

Thank you,

<image001.png> **Jeffrey Luker**, AIA, LEED AP

Principal

202 591 2509 direct

From: Steven Coffman <scoffman@luminasolar.com>
Sent: Wednesday, September 20, 2023 1:43 PM
To: Jeffrey Luker <jeffrey.luker@quinnevans.com>
Subject: Interconnection Approved! ALSO Historic application

Hey Jeff,

Quick update, your utility interconnection has been approved! Waiting on county permits and historical.

For the historical application, we still need the email(s) from Richard and the neighbor on your other side. Just a quick "yes we approve of the solar project" with their name and address will do.

Thanks!



Steve Coffman

Project Manager

301.509.4376
luminasolar.com

3600 Commerce Dr., Ste 601
Baltimore, MD 21227

Leave us a Review!

Google - Lumina Solar

SolarReviews - Lumina Solar

Facebook - Lumina Solar

Energysage - Lumina Solar

Home Advisor - Lumina Solar

2 attachments

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
Montgomery County
Historic Preservation Commission

A handwritten signature in black ink, appearing to read "Richard H. [unclear]".



image001.png
9K



image001.png
9K


REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED

Montgomery County

Historic Preservation Commission



REVIEWED
 By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
 Montgomery County
 Historic Preservation Commission

Robert A. Norton

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

SOLAR PV SYSTEM: 5.265 kWp

LUKER RESIDENCE

7307 TAKOMA AVENUE TAKOMA PARK MD
UNITED STATES 20912

PROJECT INFORMATION



OWNER: JEFFERY LUKER
ADDRESS: 7307 TAKOMA AVENUE
TAKOMA PARK MD UNITED STATES 20912

AHJ: MONTGOMERY COUNTY (MD)
ADDRESS: 2425 REEDIE DRIVE
WHEATON-GLENMONT, MARYLAND 20902

ZONING: RESIDENTIAL
BUILDING CODE: IBC 2018
ELECTRICAL CODE: NEC 2017
ASCE VERSION: ASCE 7-16

SNOW LOAD: 30 PSF
WIND SPEED: 115 MPH
WIND EXPOSURE: B

DC RATING: 5.265 kW
AC RATING: 3.77 kW
RACKING: UNIRAC SM LIGHT RAIL
MODULE: (13) REC405AA
INVERTER: (13) IQ8PLUS-72-2-US



APPROVED
Montgomery County
Historic Preservation Commission

FOR PERMITTING USE ONLY

PROJECT SCOPE

THIS PROJECT INVOLVES THE INSTALLATION OF (13) REC PURE 405W ALL BLACK SOLAR MODULES. THE SOLAR MODULES WILL BE RACKED USING A PRE-ENGINEERED RACKING SYSTEM. THE RACKED MODULES WILL BE ELECTRICALLY CONNECTED TO (13) ENPHASE DC TO AC POWER INVERTERS, AND INTERCONNECTED TO THE LOCAL UTILITY USING MEANS AND METHODS CONSISTENT WITH THE RULES ENFORCED BY THE LOCAL UTILITY AND PERMITTING JURISDICTION.

PROJECT ADDRESS:

JEFFERY LUKER
7307 TAKOMA AVENUE
TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:



3600 COMMERCE DR
SUITE 601
BALTIMORE, MD 21227
(443) 955-0779

LICENSE NUMBER:

MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/17/2023 |

COVER

Z001

| INDEX OF PAGES | |
|----------------|---------------------------|
| Z001 | COVER PAGE |
| A001 | ATTACHMENT & SITE PLAN |
| S001 | ASSEMBLY & LOAD CALCS |
| E001 | ELECTRICAL - LINE DIAGRAM |
| E002 | ELECTRICAL - WIRE CALCS |
| E003 | STRING & CONDUIT LAYOUT |
| E004 | EQUIP. RATINGS & SIGNAGE |

GENERAL NOTES

1) THIS PHOTOVOLTAIC (PV) SYSTEM SHALL COMPLY WITH THE NATIONAL ELECTRIC CODE (NEC) ARTICLE 690, ALL MANUFACTURERS'S LISTING AND INSTALLATION INSTRUCTIONS, AND THE RELEVANT CODES AS SPECIFIED BY THE AUTHORITY HAVING JURISDICTION (AHJ).

2) ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL BUILDING CODE AND AS REQUIRED BY THE NEC AND AHJ.

3) PV SYSTEM CIRCUITS INSTALLED ON OR IN BUILDINGS SHALL INCLUDE A RAPID SHUTDOWN FUNCTION TO REDUCE SHOCK HAZARD FOR EMERGENCY RESPONDERS

4) THIS SYSTEM IS A UTILITY INTERACTIVE SYSTEM, AND THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE.



STAMPED AND SIGNED FOR STRUCTURAL ONLY


DocuSigned by:
Andrew Oesterreicher
4A8006A02EA947F...

Professional Certification: I hereby certify that these documents were prepared or approved by me, and that I am a duly licensed professional engineer under the laws of the State of Maryland.
license no. 48910 expires 9/30/24

FOR ENGINEERING USE ONLY

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023



FRONT

LEGEND

| | |
|--|------------------|
| | ROOF SUPPORT |
| | MOUNTING RAIL |
| | ROOF ATTACHMENT |
| | PV ARRAY |
| | FIRECODE SETBACK |

APPROVED
Montgomery County
Historic Preservation Commission

FOR PERMITTING USE ONLY

PROJECT ADDRESS:

JEFFERY LUKER
7307 TAKOMA AVENUE
TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:



3600 COMMERCE DR
SUITE 601
BALTIMORE, MD 21227
(443) 955-0779

LICENSE NUMBER:

MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/17/2023 |

ATTACHMENT PLAN

A001

UTILITY METER
AC COMBINER
AC DISCONNECT



STAMPED AND SIGNED
FOR STRUCTURAL ONLY

DocuSigned by:

Andrew Oesterreicher

4A8006A02EA947F...

INSTALLATION NOTES

- 1) ALL SOLAR MODULES SUPPORTED BY ROOF ATTACHMENTS STAGGERED AT 48 IN O.C. (OR AS INDICATED)
- 2) SOLAR PHOTOVOLTAIC SYSTEM INSTALLED PARALLEL TO ROOF SURFACE
- 3) SOLAR PHOTOVOLTAIC SYSTEM INSTALLED AT A MAXIMUM HEIGHT OF 6 IN ABOVE ROOF SURFACE (OR AS INDICATED)



4) ANY ROOFING PENETRATIONS SHALL HAVE PROPER FLASHING SEALANT USED TO PROVIDE WATERTIGHT ASSEMBLY

TOTAL ROOF PLAN AREA = 1993.88 SQ.FT.
TOTAL SOLAR ARRAY AREA = 258.917 SQ.FT.
ARRAY ROOF COVERAGE = 13 %

FOR ENGINEERING USE ONLY

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023



APPROVED
 Montgomery County
 Historic Preservation Commission

FOR PERMITTING USE ONLY

PROJECT ADDRESS:

JEFFERY LUKER
 7307 TAKOMA AVENUE
 TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:



3600 COMMERCE DR
 SUITE 601
 BALTIMORE, MD 21227
 (443) 955-0779

LICENSE NUMBER:

MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/17/2023 |

ASSEMBLY & LOAD CALCS

S001

| ROOF PROPERTIES | ROOF LABEL: | A | B |
|--------------------------------|-----------------------------------|---------------------------|---------------------------|
| | MATERIAL: | 3-Tab Comp Shingle | 3-Tab Comp Shingle |
| | PITCH: | 46° | 46° |
| | AZIMUTH: | 209° | 119° |
| | PRIMARY SUPPORT: | 3,5x5,5 ROUGH CUT RAFTERS | 3,5x5,5 ROUGH CUT RAFTERS |
| | PRIMARY SUPPORT SPACING: | 24" | 24" |
| | SPAN (EAVE TO RIDGE): | 10.25' | 9.83' |
| | MEAN HEIGHT: | 20' | 20' |
| | RACKING: | UNIRAC SM LIGHT RAIL | UNIRAC SM LIGHT RAIL |
| | STANDOFF: | RT-MINI | RT-MINI |
| DEAD & POINT LOAD CALCULATIONS | NUMBER OF MODULES: | 8 | 5 |
| | MODULE WEIGHT (LBS): | 360.00 | 225.00 |
| | M.L.E. WEIGHT (LBS): | 19.04 | 11.90 |
| | RACKING WEIGHT (LBS): | 77.44 | 48.40 |
| | STANDOFF WEIGHT (LBS): | 12.00 | 7.50 |
| | ARRAY WEIGHT (LBS): | 468.48 | 292.80 |
| | ARRAY AREA (SQ.FT.): | 159.33 | 99.58 |
| | DISTRIBUTED LOAD (PSF): | 2.94 | 2.94 |
| | APPROX. NUMBER OF STANDOFFS: | 20 | 13 |
| | POINT LOAD (LBS/STANDOFF): | 23.42 | 22.52 |

INSTALLATION NOTES

- 1) ALL RACKING SHALL BE INSTALLED PER MANUFACTURER SPECIFICATIONS
- 2) M.L.E.'S = MODULE LEVEL ELECTRONICS (IE, POWER OPTIMIZERS, MICRO-INVERTERS, CABLES, ETC)
- 3) USE (5) 5.0X60MM ROOFING SCREWS TO MOUNT TO ROOF DECKING OR PURLIN

| MOUNTING SYSTEM PROPERTIES | |
|----------------------------|--------------------------------------|
| RACKING | UNIRAC SM LIGHT RAIL |
| STANDOFF | RT-MINI (5 SCREWS) TO DECKING/PURLIN |
| MAX. RAIL SPAN (IN) | 24 |
| MIN. FASTENER DEPTH (IN) | 0.5 |
| MAX. RAIL CANTILEVER (IN) | 8 |
| MAX. ARRAY HEIGHT (IN) | 5 |



STAMPED AND SIGNED FOR STRUCTURAL ONLY

DocuSigned by:

Andrew Oesterreicher

4A8006A02EA947F...

Professional Certification: I hereby certify that these documents were prepared or approved by me, and that I am a duly licensed professional engineer under the laws of the State of Maryland. License No. 4A8006A02EA947F... expires 8/31/26

FOR ENGINEERING USE ONLY

CONDUCTOR AND CONDUIT SCHEDULE

| TAG | WIRE SIZE | GROUND SIZE | WIRE TYPE | DESCRIPTION | CONDUIT SIZE | CONDUIT TYPE | LENGTH |
|-----|-----------|-------------|-----------|--|--------------|--------------|-----------|
| SEU | #2/0 AL | N/A | SEU | (2) PHASE CONDUCTORS & (1) NEUTRAL | N/A | N/A | 5' |
| A | #12 AWG | #6 AWG | Q-CABLE | (2) PHASE CONDUCTORS & (1) BARE COPPER IN FREE AIR | N/A | N/A | 77' (MAX) |
| B | #10 AWG | #8 AWG | THWN-2 | (2) PHASE CONDUCTORS & (1) GROUND | 0.75" | EMT | 40' |
| C | #6 AWG | #8 AWG | THWN-2 | (2) PHASE CONDUCTORS & (1) NEUTRAL & (1) GROUND | 0.75" | EMT | 5' |
| D | #10 AWG | #8 AWG | THWN-2 | (2) PHASE CONDUCTORS & (1) NEUTRAL & (1) GROUND | 0.75" | EMT | 5' |
| E | #10 AWG | #8 AWG | THWN-2 | (2) PHASE CONDUCTORS & (1) NEUTRAL & (1) GROUND | 0.75" | EMT | 5' |

EQUIPMENT SCHEDULE

| TAG | EQUIPMENT DETAILS | MOUNTING LOCATION |
|-----|--|--|
| TAP | 150 AMP SQUARE D QO MAIN SERVICE PANEL WITH 150 AMP MAIN BREAKER (150 AMP SERVICE) | SURFACE-MOUNTED ON WALL OPPOSITE UTILITY METER |
| 1 | ENPHASE COMBINER (MODEL #X-IQ-AM1-240-4) WITH CIRCUITS AS LISTED IN TABLE | MOUNTED ADJACENT TO UTILITY METER |
| 2 | 30 AMP NEMA3R NON-FUSED DISCO (MODEL #DU221RB) | MOUNTED ADJACENT TO UTILITY METER |
| 3 | 125A MBE (MODEL #QO2125BNRB) WITH 2 POLE, 20 AMP QO BREAKER | MOUNTED ADJACENT TO MAIN SERVICE PANEL |

REVIEWED
By Michael Kyne at 4:50 pm, Oct 26, 2023


APPROVED
Montgomery County
Historic Preservation Commission
[Signature]

FOR PERMITTING USE ONLY

CIRCUIT SCHEDULE

| CIRCUIT | INVERTER COUNT | AMPERAGE CALCULATION | BREAKER SIZE |
|---------|----------------|----------------------------|--------------|
| #1 | 13 | 13 x 1.21 x 125% = 19.66 A | 20 AMP (CB1) |

SOLAR MODULE; SEE PAGE E004 FOR RATINGS
MICRO-INVERTER; SEE PAGE E004 FOR RATINGS



PROJECT ADDRESS:

JEFFERY LUKER
7307 TAKOMA AVENUE
TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:

FUSION SOLAR SERVICES
3600 COMMERCE DR SUITE 601
BALTIMORE, MD 21227
(443) 955-0779

LICENSE NUMBER:
MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/18/2023 |

ELECTRICAL - LINE DIAGRAM

E001

ELECTRICAL NOTES

- WHEN THE AC UTILITY SOURCE IS REMOVED FROM THE INVERTER OUTPUT CIRCUITS VIA ANY MEANS, SUCH AS AN AC BREAKER, AC DISCONNECT, OR REMOVAL OF THE SOLAR OR MAIN UTILITY SERVICE METER, THIS EQUIPMENT PERFORMS THE RAPID SHUTDOWN FUNCTION PER 690.12
- ARRAY BONDED WITH #6 BARE Cu
- TWO UNGROUNDED CONDUCTORS PER CIRCUIT OF INVERTERS (TYP)
- ALL CONDUIT SIZING WILL BE IN ACCORDANCE TO THE NEC, CHAPTER 9
- PVC OR LFMC MAY BE USED INSTEAD OF EMT CONDUIT
- THE AC DISCONNECT IS LOCKABLE, TAGGABLE, 24/7 UTILITY ACCESSIBLE, LOAD BREAK CAPABLE, AND HAS VISIBLE BREAK.

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
Montgomery County
Historic Preservation Commission
[Signature]

FOR PERMITTING USE ONLY

| CALCULATION FOR PV BREAKER | | | | | |
|----------------------------|-------|---|------|---|-----------|
| SYSTEM CURRENT | 1.21 | x | 13 | = | 15.73 A |
| DESIGN AMPERAGE (FLA) | 15.73 | x | 125% | = | 19.6625 A |
| MAIN BUSS RATING | 150 | x | 120% | = | 180 A |
| EXISTING MAIN BREAKER | | | | | 150 A |
| MAX SOLAR BREAKER | 180 | - | 150 | = | 30 A |

| ARRAY TO COMBINER | |
|--|----------------------|
| WIRE LENGTH | 40 FT |
| WIRE SIZE | #10 AWG |
| SYSTEM PROPERTIES | |
| FULL LOAD AMPERAGE | 15.73 |
| SOURCE VOLTAGE | 240 |
| LENGTH OF RUN (FT) | 40 |
| LOAD DUTY | CONTINUOUS |
| CONDUCTOR TYPE | THWN-2 |
| CONDUCTOR MATERIAL | COPPER |
| CONDUCTOR LOCATION | DRY OR WET |
| CONDUCTOR INSULATION TEMP | 75°C |
| DISTANCE ABOVE ROOF | ALL INTERIOR CONDUIT |
| AVERAGE OUTSIDE TEMP (°F) | 94 |
| TEMP ADDER (°F) | N/A |
| ADJUSTED AMBIENT TEMP (°F) | 94 |
| TERMINAL TEMP RATING | 75°C |
| CIRCUIT TYPE | SINGLE PHASE 2-WIRE |
| QTY. OF CURRENT-CARRYING CONDUCTORS | 2 |
| ADDITIONAL CURRENT-CARRYING CONDUCTORS | |
| TOTAL # OF CURRENT-CARRYING CONDUCTORS | 2 |
| CONDUCTOR CONDITIONS OF USE | |
| LARGEST CIRCUIT FULL LOAD AMPS | 15.73 |
| LOAD DUTY MULTIPLIER | 1.25 |
| AMBIENT TEMP FACTOR | 0.94 |
| QTY. CONDUCTORS IN CONDUIT FACTOR | 1.00 |
| CONDUCTOR SELECTION | |
| MINIMUM REQUIRED CONDUCTOR AMPACITY | 20.92 |
| SELECTED CONDUCTOR AMPACITY | 35.00 |
| SELECTED CONDUCTOR SIZE (AWG) | 10 |
| TERMINAL REQUIREMENT | |
| LARGEST CIRCUIT FULL LOAD AMPS | 15.73 |
| LOAD DUTY MULTIPLIER | 1.25 |
| REQUIRED TERMINAL AMPACITY | 19.66 |
| VOLTAGE DROP | |
| OHMS/MILFT | 1.240 |
| LENGTH OF RUN (FT) | 40 |
| LOAD CURRENT | 15.73 |
| VOLTAGE DROP | 1.56 |
| VOLTS AT LOAD TERMINAL | 238.44 |
| PERCENT VOLTAGE DROP | 0.65% |

| INTERCONNECTION | |
|-------------------------------------|---------------------|
| METHOD | LINE SIDE TAP |
| WIRE SIZE | #6 AWG |
| SYSTEM PROPERTIES | |
| FULL LOAD AMPERAGE | 15.73 |
| SOURCE VOLTAGE | 240 |
| LENGTH OF RUN (FT) | 15 |
| LOAD DUTY | CONTINUOUS |
| CONDUCTOR TYPE | THWN-2 |
| CONDUCTOR MATERIAL | COPPER |
| CONDUCTOR LOCATION | DRY OR WET |
| CONDUCTOR INSULATION TEMP | 75°C |
| AMBIENT TEMP | 26-30°C |
| TERMINAL TEMP RATING | 75°C |
| CIRCUIT TYPE | SINGLE PHASE 3-WIRE |
| QTY. OF CURRENT-CARRYING CONDUCTORS | 2 |
| CONDUCTOR CONDITIONS OF USE | |
| FULL LOAD AMPS | 15.73 |
| LOAD DUTY MULTIPLIER | 1.25 |
| AMBIENT TEMP FACTOR | 1.00 |
| QTY. CONDUCTORS IN CONDUIT FACTOR | 1.00 |
| CONDUCTOR SELECTION | |
| MINIMUM REQUIRED CONDUCTOR AMPACITY | 19.66 |
| SELECTED CONDUCTOR AMPACITY | 65.00 |
| SELECTED CONDUCTOR SIZE (AWG) | 6 |
| TERMINAL REQUIREMENT | |
| FULL LOAD AMPS | 15.73 |
| LOAD DUTY MULTIPLIER | 1.25 |
| REQUIRED TERMINAL AMPACITY | 19.66 |
| VOLTAGE DROP | |
| OHMS/MILFT | 0.491 |
| LENGTH OF RUN (FT) | 15 |
| LOAD CURRENT | 15.73 |
| VOLTAGE DROP | 0.23 |
| VOLTS AT LOAD TERMINAL | 239.77 |
| PERCENT VOLTAGE DROP | 0.10% |

PROJECT ADDRESS:

JEFFERY LUKER
7307 TAKOMA AVENUE
TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:



3600 COMMERCE DR
SUITE 601
BALTIMORE, MD 21227
(443) 955-0779

LICENSE NUMBER:

MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/18/2023 |

ELECTRICAL - WIRE CALCS

E002








ELECTRICAL NOTES











1) ALL CONDUCTORS SHALL BE COPPER, RATED FOR 75°C AND WET ENVIRONMENT, UNLESS OTHERWISE NOTED.

2) ALL WIRE TERMINATIONS SHALL BE APPROPRIATELY LABELED AND READILY VISIBLE.

3) MODULE GROUNDING CLIPS TO BE INSTALLED BETWEEN MODULE FRAME AND MODULE SUPPORT RAIL, PER MANUFACTURER'S INSTRUCTION.

LEGEND

-  JUNCTION BOX
-  SOLADECK
-  END CAP
-  EXTERIOR CONDUIT
-  INTERIOR CONDUIT
-  BASEMENT CONDUIT
-  TRUNK CABLE

| COLOR | CIRCUIT | MODULE COUNT |
|---|---------|--------------|
|  | #1 | 13 |
|  | | |
|  | | |
|  | | |
|  | | |
|  | | |
|  | | |
|  | | |
|  | | |
|  | | |



REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
 Montgomery County
 Historic Preservation Commission



FOR PERMITTING USE ONLY



PROJECT ADDRESS:

JEFFERY LUKER
 7307 TAKOMA AVENUE
 TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:



FUSION
 SOLAR SERVICES

3600 COMMERCE DR
 SUITE 601
 BALTIMORE, MD 21227
 (443) 955-0779

LICENSE NUMBER:

MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/18/2023 |

CIRCUIT & CONDUIT LAYOUT

E003

| SOLAR MODULE RATINGS | |
|--|---------------|
| REC Pure 405w All Black Specifications | |
| Length: | 71.7 in |
| Width: | 40 in |
| Thickness: | 1.2 in |
| Weight: | 45.00 lbs |
| Imp: | 9.56 A |
| Vmp: | 42.4 V |
| Voc: | 48.9 V |
| Isc: | 10.14 A |
| OCPD: | 25 A |
| Pmax: | 405 W |
| Vmax: | 1000 V |
| Temp. Coefficient: | -0.24 %Voc/°C |

WARNING: PHOTOVOLTAIC POWER SOURCE

LABEL TO BE INSTALLED AT EXPOSED RACEWAYS, CABLE TRAYS, AND OTHER WIRING METHODS; SPACED AT MAXIMUM 10FT SECTION OR WHERE SEPARATED BY ENCLOSURES, WALLS, PARTITIONS, CEILINGS, OR FLOORS.

LETTERS AT LEAST 3/8 INCH; WHITE ON RED BACKGROUND; REFLECTIVE

PHOTOVOLTAIC DC DISCONNECT

LABEL TO BE INSTALLED AT EACH DC DISCONNECTING MEANS

PHOTOVOLTAIC AC DISCONNECT

LABEL TO BE INSTALLED AT EACH AC DISCONNECTING MEANS

PHOTOVOLTAIC SYSTEM EQUIPPED WITH RAPID SHUTDOWN

LABEL TO BE INSTALLED AT RAPID SHUTDOWN SWITCH

LETTERS AT LEAST 3/8 INCH; WHITE ON RED BACKGROUND; REFLECTIVE

SOLAR PV SYSTEM DISCONNECT


RATED AC OUTPUT CURRENT: 15.73 A

NOMINAL OPERATING AC VOLTAGE: 240 V

LABEL TO BE INSTALLED AT AN ACCESSIBLE LOCATION AT THE DISCONNECTING MEANS AS A POWER SOURCE

SOLAR PV SYSTEM IS EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUT DOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN ARRAY.



LABEL TO BE INSTALLED ON NO MORE THAN 3FT FROM THE SERVICE DISCONNECTING MEANS

WARNING

ELECTRICAL SHOCK HAZARD

DO NOT TOUCH TERMINALS! TERMINALS ON BOTH LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION

LABEL TO BE INSTALLED AT EACH DISCONNECTING MEANS FOR PHOTOVOLTAIC EQUIPMENT

WARNING

ELECTRICAL SHOCK HAZARD

IF GROUND FAULT IS INDICATED NORMALLY GROUNDED CONDUCTORS MAY BE UNGROUNDED AND ENERGIZED

LABEL TO BE INSTALLED AT EACH DISCONNECTING MEANS FOR PHOTOVOLTAIC EQUIPMENT

WARNING

DUAL POWER SOURCE SECOND SOURCE IS PHOTOVOLTAIC SYSTEM

LABEL TO BE INSTALLED ON EXTERIOR OF MAIN ELECTRICAL PANEL

WARNING

INVERTER OUTPUT CONNECTION. DO NOT RELOCATE THIS OVERCURRENT DEVICE

LABEL TO BE APPLIED TO THE DISTRIBUTION EQUIPMENT

INTERACTIVE PHOTOVOLTAIC SYSTEM CONNECTED

LABEL TO BE INSTALLED AT UTILITY METER

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED


Montgomery County
Historic Preservation Commission

FOR PERMITTING USE ONLY

PROJECT ADDRESS:

JEFFERY LUKER
7307 TAKOMA AVENUE
TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:



FUSION SOLAR SERVICES

3600 COMMERCE DR
SUITE 601
BALTIMORE, MD 21227
(443) 955-0779

LICENSE NUMBER:

MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/18/2023 |

EQUIP. RATINGS & SIGNAGE

E004

**SOLAR PV LOADCENTER
5.265 kW DC SOLAR ARRAY
240 VOLT AC SYSTEM**

INSTALLED COMPONENTS

(13) REC Pure 405w All BlackW Modules
(13) Enphase IQ8+

EMERGENCY CONTACT

LUMINA SOLAR: 800-971-6118

CIRCUIT CALCULATIONS

| | | | | | |
|------------------|-------|---|-------|---|-----------|
| SYSTEM CURRENT: | 1.21 | x | 13 | = | 15.73 A |
| DESIGN AMPERAGE: | 15.73 | x | 125% | = | 19.6625 A |
| CIRCUIT #1 = | 13 | | 15.73 | | 19.66 |

SIGNAGE NOTES

- 1) ALL PLAQUES AND LABELS SHALL HAVE A RED BACKGROUND (OR AS SHOWN HERE)
- 2) ALL LETTERING SHALL BE WHITE AND HAVE A MINIMUM HEIGHT OF 3/8" (OR AS SHOWN HERE)
- 3) FONT SHALL BE ARIAL (OR SIMILAR) AND ALL LETTERING SHALL BE CAPITALIZED
- 4) ALL PLAQUES AND LABELS SHALL BE OF A MATERIAL SUITABLE FOR THE ENVIRONMENT INSTALLED

RAPID SHUTDOWN SWITCH FOR SOLAR PV SYSTEM

LABEL TO BE INSTALLED ON OR NO MORE THAN 3FT FROM THE RAPID SHUTDOWN SWITCH

MODULES, INVERTERS, MISC COMPONENTS

| PRODUCT | QTY |
|----------------------------|-----|
| REC Pure 405w All Black | 13 |
| EnPhase IQ8+ Microinverter | 13 |
| Enphase Consumption CTs | 2 |

RACKING & ATTACHMENTS

| PRODUCT | QTY |
|--|-----|
| 14' Light Rail DRK (315168D) | 7 |
| 20' Light Rail DRK (315240D) | 2 |
| Unirac Bnd Splice Bar Kit (Serrated Drk) | 1 |
| Small Endclamps 30-32mm | 20 |
| Small Midclamps 30-36mm | 16 |
| | |
| | |
| | |
| TBRW-80 T-bolts + Nuts | 68 |
| RT-Mini II Base | 68 |
| M8-1.25 Flanged Bolt + Nut | 68 |
| RT-Mini II 5.0X60mm Screws | 340 |
| EcoFasten L-102-3 L Foot Black | 68 |
| | |
| | |
| Micro-Inverter Mounting Assembly (Bolt+Nut+Washer) | 13 |
| Grounding Weebug | 5 |

MISCELLANEOUS & MANUAL ADDITIONS

| PRODUCT | QTY |
|------------------------------|-----|
| Lumina Salesperson Yard Sign | 1 |
| Duct Seal | |
| Geocel 4500 Caulk/Sealant | |

COMBINERS, DISCONNECTS, ENCLOSURES

| PRODUCT | QTY |
|--|-----|
| Soladeck | 2 |
| | |
| | |
| Enphase Combiner (Model #X-IQ-AM1-240-4) | 1 |
| 30 Amp Nema3r Non-Fused Disco (Model #DU221RB) | 1 |
| 125A MBE (Model #QO2125BNRB) | 1 |

BREAKERS, FUSES, TAPS

| PRODUCT | QTY |
|---------------------------------------|-----|
| 2 pole, 20 Amp Breaker (For Combiner) | 1 |
| | |
| B-Tap 2/0-10 | 2 |
| 2 pole, 20 Amp QO Breaker | 1 |
| | |
| | |

EMT/FMC CONDUIT & ENCLOSURE FITTINGS

| PRODUCT | SIZE (IN) & QUANTITY | | | | | | | |
|--|----------------------|------|---|------|-----|---|-----|---|
| | 0.5 | 0.75 | 1 | 1.25 | 1.5 | 2 | 2.5 | 3 |
| FMC (Greenfield) Straps | | 12 | | | | | | |
| Straight Connector - Squeeze Clamp with Locknut | | 8 | | | | | | |
| One-Hole Rigid Conduit Straps | | 18 | | | | | | |
| Rigid Conduit Compression Coupler | | 4 | | | | | | |
| EMT Compression Connector with Locknut & Rubber Gasket | | 11 | | | | | | |
| LB-Type EMT Conduit Body | | 1 | | | | | | |
| LL/LR-Type EMT Conduit Body | | 2 | | | | | | |
| Square D B-Hub | | 2 | | | | | | |
| EMT Grounding Locknut | | 10 | | | | | | |
| Exterior Conduit Roof Mount Assemblies (RTs, RT Screws (5 per) OR Metal Brackets for Metal Roofs OR Foam Blocks) | | | | | | | | |
| Strain Relief Cord Connector with Insulating Plastic Bushing | | | | | | 3 | | |

NOTES

USE 'BR' BREAKERS IN ENPHASE COMBINER

USE APPROPRIATE BREAKERS IN NON-ENPHASE COMBINER PANELS

SEE FOLLOWING PAGE FOR WIRE AND CONDUIT TYPES AND LENGTHS

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED

Montgomery County
Historic Preservation Commission

FOR PERMITTING USE ONLY

PROJECT ADDRESS:

JEFFERY LUKER
 7307 TAKOMA AVENUE
 TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:



3600 COMMERCE DR
SUITE 601
BALTIMORE, MD 21227
(443) 955-0779

LICENSE NUMBER:

MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/18/2023 |

SOLAR BOM

X001

INSTALL LEAD SIGNATURE: _____ DATE: _____

CONDUCTOR SCHEDULE

| | | PRODUCT | | | | QTY | | | |
|------------|----------|-----------------------------------|------------|------------|----------|------------|------------|------------|--|
| | | Enphase IQ Trunk Cable, Landscape | | | | 13 UNITS | | | |
| | | #6 Bare Copper Ground | | | | 35 FT | | | |
| | | #18 AWG Cu, 7 Strand (CT Wiring) | | | | 30 FT | | | |
| SIZE (AWG) | THWN-2 | | | | XHHW-2 | | | | |
| | RED (FT) | BLACK (FT) | WHITE (FT) | GREEN (FT) | RED (FT) | BLACK (FT) | WHITE (FT) | GREEN (FT) | |
| 18 | | | | | | | | | |
| 16 | | | | | | | | | |
| 14 | | | | | | | | | |
| 12 | | | | | | | | | |
| 10 | 80 | 80 | 10 | | | | | | |
| 8 | | | | 85 | | | | | |
| 6 | 5 | 5 | 5 | | | | | | |
| 4 | | | | | | | | | |
| 3 | | | | | | | | | |
| 2 | | | | | | | | | |
| 1 | | | | | | | | | |
| 1-0 | | | | | | | | | |
| 2-0 | | | | | | | | | |
| 3-0 | | | | | | | | | |
| 4-0 | | | | | | | | | |
| 250 | | | | | | | | | |
| 300 | | | | | | | | | |
| 350 | | | | | | | | | |
| 400 | | | | | | | | | |
| 500 | | | | | | | | | |
| 600 | | | | | | | | | |
| 700 | | | | | | | | | |
| 750 | | | | | | | | | |
| 800 | | | | | | | | | |
| 900 | | | | | | | | | |
| 1000 | | | | | | | | | |
| 1250 | | | | | | | | | |
| 1500 | | | | | | | | | |
| 1750 | | | | | | | | | |
| 2000 | | | | | | | | | |

CONDUIT SCHEDULE

| SIZE (IN) | TYPE AND LENGTH (FT) | | | |
|-----------|----------------------|-----|-----|------|
| | PVC | EMT | FMC | LFMC |
| 0.50 | | | | |
| 0.75 | | 40 | 45 | |
| 1.00 | | | | |
| 1.25 | | | | |
| 1.50 | | | | |
| 2.00 | | | | |
| 2.50 | | | | |
| 3.00 | | | | |

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
 Montgomery County
 Historic Preservation Commission

FOR PERMITTING USE ONLY

PROJECT ADDRESS:

JEFFERY LUKER
 7307 TAKOMA AVENUE
 TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:



3600 COMMERCE DR
 SUITE 601
 BALTIMORE, MD 21227
 (443) 955-0779

LICENSE NUMBER:

MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/18/2023 |

WIRE & CONDUIT BOM

X002

INSTALL LEAD SIGNATURE: _____ DATE: _____

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
Montgomery County
Historic Preservation Commission




FOR PERMITTING USE ONLY

PROJECT ADDRESS:

JEFFERY LUKER
7307 TAKOMA AVENUE
TAKOMA PARK MD UNITED
STATES 20912

CONTRACTOR INFO:



FUSION
SOLAR SERVICES

3600 COMMERCE DR
SUITE 601
BALTIMORE, MD 21227
(443) 955-0779

LICENSE NUMBER:

MHIC-30991

REV **DATE**

IFC 8/18/2023

SERVICE BOM

X003

(PAGE LEFT INTENTIONALLY BLANK)

INSTALL LEAD SIGNATURE: _____ DATE: _____

RAIL AND SPLICE QUANTITY COUNTING METHOD

| Module Count | PORTRAIT | | | LANDSCAPE | | |
|--------------|----------|----------|--------|-----------|----------|--------|
| | 14' Rail | 20' Rail | Splice | 14' Rail | 20' Rail | Splice |
| 1 | 1 | | | 1 | | |
| 2 | | 1 | | 2 | | |
| 3 | 2 | | | | 2 | |
| 4 | 1 | 1 | 1 | 4 | | 2 |
| 5 | | 2 | | 2 | 2 | 2 |
| 6 | 2 | 1 | 2 | | 4 | 2 |
| 7 | 1 | 2 | 2 | 2 | 3 | 4 |
| 8 | | 3 | 2 | | | |
| 9 | 2 | 2 | 2 | | | |
| 10 | | 4 | 2 | | | |
| 11 | | 4 | 2 | | | |
| 12 | 2 | 3 | 4 | | | |

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
 Montgomery County
 Historic Preservation Commission

FOR PERMITTING USE ONLY



PROJECT ADDRESS:

JEFFERY LUKER
 7307 TAKOMA AVENUE
 TAKOMA PARK MD UNITED STATES 20912

CONTRACTOR INFO:



3600 COMMERCE DR
 SUITE 601
 BALTIMORE, MD 21227
 (443) 955-0779

LICENSE NUMBER:

MHIC-30991

| REV | DATE |
|-----|-----------|
| IFC | 8/18/2023 |

PROJECT NOTES

X004



REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

AOstructures Inc.
PO Box 413

APPROVED
Montgomery County
Historic Preservation Commission

August 17, 2023

TO: Lumina Solar
SUBJECT: Roof-top Solar PV Addition - Luker Residence
7307 Takoma Ave., Takoma Park, MD. 20912

SCOPE OF WORK:

AOstructures, Inc. was asked to provide a structural review for the project at the above subject location. The scope of this report is strictly limited to the items listed below and based on the design criteria listed below. See additional limitations in Appendix B.

- Analyze the existing structure(s) to see if it is/they are suitable to support the additional weight of the proposed roof mounted solar PV system.
- Evaluate the connection capacity of the proposed racking system to the existing roof structure.

PROVIDED INFORMATION:

As-built plans were not provided for our review. The findings of this report are based upon a jobsite evaluation of the existing condition of the existing framing system collected by Lumina Solar as requested by AOstructures, Inc.. All attached structural calculations are based on the provided information and are only deemed valid if the provided information is true and accurate.

OBSERVED CONDITIONS:

The observed roof framing is described below. If field conditions differ, the contractor shall notify the engineer prior to starting construction.

The roof structure of (Both Roof's) consists of composition shingle on roof plywood and skip sheathing that is supported by 2"x6" rafters @ 24"o.c. with ceiling joists acting as rafter ties. The rafters have a max projected horizontal span of 13'-6", with a slope of 45 degrees. The rafters are connected at the ridge to a ridge board and are supported at the eave by a load bearing wall.

CONCLUSIONS:

The existing roof framing members of (Both Roof's) are judged to be adequate to withstand the loading imposed by the installation of the solar panels. No structural retrofits are required.

The spacing of the solar standoffs shall not exceed 24" o.c. and be staggered. All racking hardware shall be installed per manufacturer specifications and utilized within the manufacturers design limitations based on the design criteria of this report. AOstructures, Inc. assumes no responsibility for hardware installed outside the design & install specifications of the manufacturer. All waterproofing shall be provided by the contractor.

DESIGN CRITERIA:

- Applicable Codes = 2018 IBC/IRC, ASCE 7-16
- 66 cell solar PV modules w/ a flush mounted rail based racking system
- Roof Dead Load = 11 psf (Both Roof's)
- Roof Live Load = 20 psf
- Wind Speed = 115 mph, Exposure B, Risk Category II
- Ground Snow Load = 30 psf - Roof Snow Load = 13.2 psf
- Per IBC 1613.1; Seismic check is not required

Please contact me with any further questions or concerns regarding this project.

Sincerely,

DocuSigned by:

Andrew Oesterreicher

4A8006A02EA947F...

Andrew Oesterreicher, P.E.
Project Engineer



Professional Certification: I hereby certify that these documents were prepared or approved by me, and that I am a duly licensed professional engineer under the laws of the State of Maryland.
License No. 49910 Expires: 9/15/24



AOstructures Inc.
PO Box 413
Carnelian Bay, CA 96140
916.541.8586
www.AOstructures.com

Address: 7307 Takoma Ave., Takoma Park, MD. 20912

Wind Design

Exposure: B
Wind Speed: 115 mph
Risk Category: II

Aerial Image



REVIEWED
By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
Montgomery County
Historic Preservation Commission



AOstructures Inc.
PO Box 413
Carnelian Bay, CA 96140
916.541.8586
www.AOstructures.com

Wind Calculations

Per ASCE 7-16 § 29.4.4 - Components and Cladding - Solar Specific

Input Variables

| | | | |
|-------------------|---------|---------------------|-------------------------|
| Wind Speed | 115 mph | Roof Slope | 45 deg |
| Exposure Category | B | Mean Roof Height | 30 ft |
| Roof Shape | Gable | Effective Wind Area | 6.2 sft (standoff area) |

Design Wind Pressure Calculations

Wind Pressure $P = qh (GCp) (\gamma_e) (\gamma_a)$ (Eq. 29.4-7)

$qh = 0.00256 * Kz * Kzt * Kd * Ke * V^2$ (Eq. 26.10-1)

Kz (Exposure Coefficient) = 0.7 (Table 26.10-1)

Kzt (topographic factor) = 1 (Fig. 26.8-1)

Kd (Wind Directionality Factor) = 0.85 (Table 26.6-1)

Ke (Ground Elevation Factor) = 1 (Table 26.9-1)

V (Design Wind Speed) = 115 mph (Fig. 26.5-1)

Risk Category = II (Table 1.5-1)

(γ_e) Array Edge Factor = 1.00 29.4.4

(γ_a) Solar Panel Pressure Equalization = 0.80 (Figure 29.4-8)

$qh (\gamma_e) (\gamma_a) = 16.12$ Ultimate Design Level

$0.6 * qh (\gamma_e) (\gamma_a) = 9.67$ ASD Design Level

Standoff Uplift Calculations (ASD Level)

| | | | | |
|------------------------------|---------------|---------------|---------------|---------------------|
| Zone(s) = | 3r | 2n, 2r, 3e | 1, 2e | (+) |
| $GCp =$ | -2.88 | -2.00 | -1.80 | 0.90 (Fig. 30.3-2D) |
| ASD Uplift Pressure (psf) = | -27.88 | -19.34 | -17.40 | 10.00 |
| X Tributary Width (ft) = | 1.33 | 2.00 | 2.00 | |
| Y Tributary Width (ft) = | 3.09 | 3.09 | 3.09 | |
| Tributary Area (sf) = | 4.11 | 6.17 | 6.17 | |
| Footing Uplift (lb) = | -114.7 | -119.4 | -107.4 | |

Standoff Uplift Check

Maximum Uplift = -119 lb

$0.6 * DL$ Resisting = 11 lb

Net Design Uplift = -108 lb

Standoff Uplift Capacity = 138 lb

138 lb capacity > 108 lb demand **Therefore, OK**

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
Montgomery County
Historic Preservation Commission



AOstructures Inc.
PO Box 413
Carnelian Bay, CA 96140
916.541.8586
www.AOstructures.com

GRAVITY LOADS

Roof Snow Load Calculations

| | | |
|---|-----------------|---------------------|
| Unobstructed, Slippery Roof Surface? | no | |
| Roof Slope | 45 degrees | |
| p_g = Ground Snow Load = | 30.0 psf | |
| $p_f = 0.7 C_e C_t I p_g$ | | (ASCE7 - Eq 7-1) |
| C_e = Exposure Factor = | 1.0 | (ASCE7 - Table 7-2) |
| C_t = Thermal Factor = | 1.0 | (ASCE7 - Table 7-3) |
| I = Importance Factor = | 1.0 | (ASCE7 - 7.3.3) |
| p_f = Flat Roof Snow Load = | 21.0 psf | |
| $p_s = C_s p_f$ | | (ASCE7 - Eq 7-2) |
| C_s = Slope Factor = | 0.63 | (ASCE7 - Fig. 7-2) |
| p_s = Sloped Roof Snow Load = | 13.1 psf | |

PV Dead Load = 3 psf (Per Lumina Solar)

Roof Dead Load (Both Roof's)

| | |
|------------------------------------|----------------------------|
| Composition Shingle | 4.00 psf |
| Roof Plywood and Skip Sheathing | 3.50 |
| 2"x6" Rafters @ 24"o.c. | 1.67 |
| Vaulted Ceiling | 0.00 (Ceiling Not Vaulted) |
| Miscellaneous | 1.83 |
| Total Roof DL (Both Roof's) | 11.0 psf |
| DL Adjusted to 45 Degree Slope | 15.6 psf |

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED

Montgomery County
Historic Preservation Commission




AOstructures Inc.
 PO Box 413
 Carnelian Bay, CA 96140
 916.541.8586
 www.AOstructures.com

FRAMING CHECK

(Both Roofs)

PASS

Dead Load 15.6 psf
 PV Load 3.0 psf
 Snow Load 13.2 psf



Governing Load Combo = DL + LL
Total Load 38.6 psf

| Member Properties | | | | |
|-------------------|----------------------|----------------------|--------------|----------------|
| Member Size | S (in ³) | I (in ⁴) | Lumber Sp/Gr | Member Spacing |
| 2"x6" | 12.00 | 36.00 | SP#2 | @ 24" o.c. |

| Check Bending Stress | | | | | | | | |
|----------------------|------|---|------|---|-----|---|------|-------------------|
| Fb (psi) = | fb | x | Cd | x | Cf | x | Cr | (NDS Table 4.3.1) |
| | 1000 | x | 1.25 | x | 1.3 | x | 1.15 | |

Allowed Bending Stress = 1868.7 psi

Maximum Moment = $(wL^2) / 8$
 = 1756.724 ft#
 = 21080.68 in#

Actual Bending Stress = (Maximum Moment) / S
 = 1756.8 psi

Allowed > Actual -- 94.1% Stressed -- Therefore OK

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED

Montgomery County
 Historic Preservation Commission



Deflection Criteria Based on = **Simple Span**
 Actual Deflection (Total Load) = $(5*w*L^4) / (384*E*I)$
 = 1.144 in
 = L/142 > L/120 **Therefore OK**

Allowed Deflection (Live Load) = **L/180**
 0.9 in
 Actual Deflection (Live Load) = $(5*w*L^4) / (384*E*I)$
 0.594 in
 L/273 > L/180 **Therefore OK**

| Check Shear | | |
|------------------------------------|-----------------------------|----------------|
| Member Area = 12.0 in ² | Fv (psi) = 175 psi | (NDS Table 4A) |
| Allowed Shear = Fv * A = 2100 lb | Max Shear (V) = w * L / 2 = | 521 lb |

Allowed > Actual -- 24.8% Stressed -- Therefore, OK



AOstructures Inc.
PO Box 413
Carnelian Bay, CA 96140
916.541.8586
www.AOstructures.com

Appendix A: Framing Information & Site Specific Pictures



REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
Montgomery County
Historic Preservation Commission

A handwritten signature in black ink, appearing to read 'Robert H. ...', written over a horizontal line.



AOstructures Inc.
 PO Box 413
 Carnelian Bay, CA 96140
 916.541.8586
 www.AOstructures.com

Appendix B: General Notes

GENERAL

- The contractor shall verify all dimensions, property setbacks, AHJ/HOA CC&R's, elevations and site conditions before starting work and shall notify AOstructure, Inc. (AOstructures) of any discrepancies.
- All report conclusions represent AOstructures, Inc.'s best professional judgment based upon industry standards.
- Resolve any conflicts on the drawings with AOstructures, Inc before proceeding with construction.
- The design criteria used for this project & listed on the first page of the report is based on the engineers best judgement and/or provided by the ATC council. AHJ specific requests may differ. Please contact our team if the design criteria needs to be modified.
- A site visit was not physically conducted by AOstructures. The accompanying calculations and certification are provided with the understanding that the site building and construction standards meet an acceptable level of industry standards. It shall be the contractors responsibility to identify any irregularities such as inconsistent framing conditions, water damage, fire damage, cracked, split or noticeably deflecting framing members.
- AOstructures is not responsible for enforcing safety measures or regulations. The contractor shall design, construct, and maintain all safety devices including shoring and bracing, and shall be solely responsible for conforming to all local, state and federal safety and health standards, laws and regulations. The contractor shall take necessary precautions to maintain and insure the integrity of the structure during construction. If a lawsuit is filed by one of the contractor's or subcontractor's employees, or any one else, the contractor will indemnify, defend and hold the owner and aostructures, inc harmless of any and all such claims.
- Any and all waterproofing shall be provided by the contractor. AOstrctures is not responsible for waterproofing.
- All hardware shall be installed per manufacturer specifications and within specified design limitations. AOstructures, Inc. assumes no responsibility for incorrectly installed hardware or hardware installed outside of the manufacturer specifications.

USER RELIANCE

- AOstructures was engaged by Lumina Solar (Client) to perform this assessment. This report and the information therein, are for the exclusive use of the Client. This report has no other purpose and shall not be relied upon, or used, by any other person or entity without the written consent of AOstructures. Third parties that obtain this report, or the information within shall have no rights of recourse or recovery against AOstructures, it's officers or employees.

ROOF MOUNTED ARRAY'S

- If an analysis of a supporting stucture is included in our scope of work, the structural assessment only applies to the section of the roof that is directly supporting the proposed solar PV system.
- No structural members can be cut for conduit, etc., unless specifically shown. Obtain prior written approval for installation of any additional conduit, etc.
- It is assumed that a standard quality of construction care was used to construct the original building. It shall be the contractors responsibility to field verify any and all framing member supporting the proposed PV array are in adequate condition. The contractor shall field inspect for sub-standard construction means, signs of dryrot, mold, fire damage, etc. and notify engineer if any compromised material is found on site prior to starting construction.
- It is assumed that there have been no additional loads (HVAC or MEP equipment, additional layers of roofing, etc) added to the building over the course of the structures histroy. The contractor and/or client shall verify this with the property owner and notify AOstructures, Inc. if additional load has been added to the structure already.
- Flexible utility connections must be used at any building seismic joint.
- Care should be taken to ensure that PV arrays do not preclude drainage of rain water.
- Unless otherwise noted, construction material shall be evenly distributed if placed on framed floors or roofs. Loads shall not exceed the allowable loading for the supporting members and their connections.
- All lags or wood screws at the roof shall be stainless steel and installed withing the middle 1/3 of the dimensional width of the framing members.
- All fasteners shall be a minimum of 6" away from any truss panel or hinge joints, truss plates and/or member ends. Field verify location of fasteners prior to starting construction. All fasteners shall be pre-drilled to avoid splitting existing lumber.
- Unless otherwise noted, all lags installed in underlying roof framing members shall be embedded framing.
- AOstructures is not responsible for downslope effects of snow shedding or sliding off of the PV array. If snow guards are requested by the customer, notify customer of the cost of snow guards. Snow guards are not required for landscaping, automobiles, pets, people, etc.. If snow guards are requested by the customer, notify customer of the cost of snow guards.

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED
 Montgomery County
 Historic Preservation Commission

Luker, Jeffery, Takoma Park, MD 7

SOLAR'S MOST TRUSTED



REVIEWED


By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED

Montgomery County
Historic Preservation Commission

inter
**solar
award**

2022
WINNER



COMPACT PANEL SIZE

REC ALPHA[®] PURE SERIES PRODUCT SPECIFICATIONS

410 WP
222 W/M²



ELIGIBLE


LEAD-FREE
ROHS COMPLIANT


EXPERIENCE
α
PERFORMANCE

REC ALPHA PURE SERIES

PRODUCT SPECIFICATIONS

GENERAL DATA

| | |
|---------------|---|
| Cell type: | 132 half-cut REC heterojunction cells with lead-free, gapless technology, 6 strings of 22 cells in series |
| Glass: | 3.2 mm solar glass with anti-reflective surface treatment in accordance with EN 12150 |
| Backsheet: | Highly resistant polymer (black) |
| Frame: | Anodized aluminum (black) |
| Junction box: | 3-part, 3 bypass diodes, lead-free IP68 rated, in accordance with IEC 62790 |
| Connectors: | Stäubli MC4 PV-KBT4/KST4 (4 mm ²) in accordance with IEC 62852, IP68 only when connected |
| Cable: | 4 mm ² solar cable, 1.1 m + 1.2 m in accordance with EN 50618 |
| Dimensions: | 1821 x 1016 x 30 mm (1.85 m ²) |
| Weight: | 20.5 kg |
| Origin: | Made in Singapore |



ELECTRICAL DATA

Product Code*: RECxxxAA Pure

| | 390 | 395 | 400 | 405 | 410 |
|--|-------|-------|-------|-------|-------|
| Power Output - P _{MAX} (Wp) | 390 | 395 | 400 | 405 | 410 |
| Watt Class Sorting - (W) | 0/+5 | 0/+5 | 0/+5 | 0/+5 | 0/+5 |
| Nominal Power Voltage - V _{MPP} (V) | 40.6 | 41.0 | 41.4 | 41.8 | 42.2 |
| Nominal Power Current - I _{MPP} (A) | 9.61 | 9.64 | 9.67 | 9.69 | 9.72 |
| Open Circuit Voltage - V _{OC} (V) | 48.4 | 48.6 | 48.8 | 49.1 | 49.4 |
| Short Circuit Current - I _{SC} (A) | 10.38 | 10.39 | 10.40 | 10.41 | 10.42 |
| Power Density (W/m ²) | 211 | 214 | 216 | 219 | 222 |
| Panel Efficiency (%) | 21.1 | 21.4 | 21.6 | 21.9 | 22.2 |

| | 297 | 301 | 305 | 308 | 312 |
|--|------|------|------|------|------|
| Power Output - P _{MAX} (Wp) | 297 | 301 | 305 | 308 | 312 |
| Nominal Power Voltage - V _{MPP} (V) | 38.3 | 38.6 | 39.0 | 39.4 | 39.8 |
| Nominal Power Current - I _{MPP} (A) | 7.77 | 7.79 | 7.82 | 7.83 | 7.85 |
| Open Circuit Voltage - V _{OC} (V) | 45.6 | 45.8 | 46.0 | 46.3 | 46.6 |
| Short Circuit Current - I _{SC} (A) | 8.38 | 8.39 | 8.40 | 8.41 | 8.42 |

Values at standard test conditions (STC: air mass AM 1.5, irradiance 1000 W/m², temperature 25°C), based on a production spread with a tolerance of P_{MAX}, V_{OC} & I_{SC} ±3% within one watt class. Nominal module operating temperature (NMOT: air mass AM 1.5, irradiance 800 W/m², temperature 20°C, windspeed 1 m/s). * Where xxx indicates the nominal power class (P_{MAX}) at STC above.

MAXIMUM RATINGS

| | |
|----------------------------|-------------------------------------|
| Operational temperature: | -40 ... +85°C |
| Maximum system voltage: | 1000 V |
| Maximum test load (front): | + 7000 Pa (713 kg/m ²)* |
| Maximum test load (rear): | - 4000 Pa (407 kg/m ²)* |
| Max series fuse rating: | 25 A |
| Max reverse current: | 25 A |

* See installation manual for mounting instructions.
Design load = Test load / 1.5 (safety factor)

WARRANTY

| | Standard | REC ProTrust |
|--|----------|------------------|
| Installed by an REC Certified Solar Professional | No | Yes |
| System Size | All | ≤25 kW 25-500 kW |
| Product Warranty (yrs) | 20 | 25 |
| Power Warranty (yrs) | 25 | 25 |
| Labor Warranty (yrs) | 0 | 25 |
| Power in Year 1 | 98% | 98% |
| Annual Degradation | 0.25% | 0.25% |
| Power in Year 25 | 92% | 92% |

The REC ProTrust Warranty is only available on panels purchased through an REC Certified Solar Professional installer. Warranty conditions apply. See www.recgroup.com for more details.

CERTIFICATIONS

| | |
|---|------------------------------------|
| IEC 61215:2016, IEC 61730:2016, UL 61730 | |
| IEC 62804 | PID |
| IEC 61701 | Salt Mist |
| IEC 62716 | Ammonia Resistance |
| ISO 11925-2 | Ignitability (Class E) |
| IEC 62782 | Dynamic Mechanical Load |
| IEC 61215-2:2016 | Hailstone (35mm) |
| IEC 62321 | Lead-free acc. to RoHS EU 863/2015 |
| ISO 14001, ISO 9001, IEC 45001, IEC 62941 | |



TEMPERATURE RATINGS*

| | |
|---|-------------|
| Nominal Module Operating Temperature: | 44°C (±2°C) |
| Temperature coefficient of P _{MAX} : | -0.24 %/°C |
| Temperature coefficient of V _{OC} : | -0.24 %/°C |
| Temperature coefficient of I _{SC} : | 0.04 %/°C |


* The temperature coefficients stated are linear values

DELIVERY INFORMATION

| | |
|--|------------------|
| Panels per pallet: | 33 |
| Panels per 40 ft GP/high cube container: | 792 (24 pallets) |
| Panels per 13.6 m truck: | 924 (28 pallets) |
| Panels per 53 ft truck: | 891 (27 pallets) |

LOW LIGHT BEHAVIOUR

Typical low irradiance performance of module at STC:



Available from:

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

Founded in 1996, REC Group is an international pioneering solar energy company dedicated to empowering consumers with clean, affordable solar power. As Solar's Most Trusted, REC is committed to high quality, innovation, and a carbon footprint in the solar materials and solar panels it manufactures. Headquartered in Norway with operational headquarters in Singapore, REC also has regional hubs in North America, Europe, and Asia-Pacific.

APPROVED
Montgomery County
Historic Preservation Commission



IQ8 and IQ8+ Microinverters

Our newest IQ8 Microinverters are the industry’s first microgrid-forming, software-defined microinverters with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semiconductor-based microinverter is our proprietary application-specific integrated circuit (ASIC) which enables the microinverter to operate in grid-tied or off-grid modes. This chip is built in advanced 55nm technology with high speed digital logic and has super-fast response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Part of the Enphase Energy System, IQ8 Series Microinverters integrate with the Enphase IQ Battery, Enphase IQ Gateway, and the Enphase App monitoring and analysis software.



IQ8 Series Microinverters redefine reliability standards with more than one million cumulative hours of power-on testing, enabling an industry-leading limited warranty of up to 25 years.



Connect PV modules quickly and easily to IQ8 Series Microinverters using the included Q-DCC-2 adapter cable with plug-n-play MC4 connectors.



IQ8 Series Microinverters are UL Listed as PV Rapid Shut Down Equipment and conform with various regulations, when installed according to manufacturer’s instructions.

Easy to install

- Lightweight and compact with plug-n-play connectors
- Power Line Communication (PLC) between components
- Faster installation with simple two-wire cabling

High productivity and reliability



- Produce power even when the grid is down
- More than one million cumulative hours of testing
- Class II double-insulated enclosure
- Optimized for the latest high-powered PV modules

REVIEWED
By Michael Kyne at 4:50 pm, Oct 26, 2023



1/4" BOLT LOCATION

3/8" BOLT LOCATION



1 11/16"

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

APPROVED

Montgomery County
Historic Preservation Commission

PART # TABLE

| P/N | DESCRIPTION | LENGTH |
|---------|-------------------------|--------|
| 315168M | SM LIGHT RAIL 168" MILL | 168" |
| 315168D | SM LIGHT RAIL 168" DRK | 168" |
| 315240M | SM LIGHT RAIL 240" MILL | 240" |
| 315240D | SM LIGHT RAIL 240" DRK | 240" |



1411 BROADWAY BLVD, NE
ALBUQUERQUE, NM 87102 USA
PHONE: 505.242.6411
WWW.UNIRAC.COM

PRODUCT LINE: SOLARMOUNT

DRAWING TYPE: PART DETAIL

DESCRIPTION: LIGHT RAIL

REVISION DATE: 9/11/2017

DRAWING NOT TO SCALE
ALL DIMENSIONS ARE
NOMINAL

PRODUCT PROTECTED BY
ONE OR MORE US PATENTS
LEGAL NOTICE

SM-P02

SHEET

RT-MINI

Self-flashing base for asphalt & metal roof-top PV mounting systems

RT-MINI is suitable for mounting any rail system with a conventional L-Foot.



Dual bolt design: M8 or 5/16" for L-Foot & 1/4" for EMT or accessories



ICC ESR 3575


Call Now for more details

858-935-6064

REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023

Easy tapping screw guide
1/4" Hex Bolt upper channel



APPROVED

Montgomery County

Historic Preservation Commission

RT-MINI

Flexible Flashing certified by the International Code Council (ICC)

Engineered to **ASTM D 1761** (Standard Test Methods for Mechanical Fasteners in Wood)

Components

RT2-00-MINIBK



PAT : PENDING



MINI base : 20 ea.

Screw : 40 ea.

Extra RT-Butyl : 10 ea.

Optional items:


5 x 60mm Mounting screw (RT2-04-SD5-60) : 100 ea/Bag

5/16" Hex bolt, washer & nut set (RT-04-BN30SL-US) : 100 ea/Bag

RT-Butyl (RT2-04-BUTYLT) : 10 ea/Box


RT-Butyl is Roof Tech's flexible flashing used in 700,000 residential PV systems for the last 24 years. It is the first PV mounting system with Flexible Flashing certified by the ICC.

Metal Flashing Retrofit



Shedding water?

Flexible Flashing



100% Waterproof


ICC ESR-3575 ASTM2140 testing UV testing (7500 hrs.)




REVIEWED

By Michael Kyne at 4:50 pm, Oct 26, 2023


Dimensions in (mm)



Rafter installation



Deck installation



Weight:

Mini- 158.4 g

1 screw- 8.7g

Bolt and nut - 20.4 g

APPROVED

Montgomery County

Historic Preservation Commission

P.B. Stamp

/support

Roof & Tech, Inc.
www.roof-tech.us info@
10620 Trenea Street, Suite 230, Sar
858.935.6064