



HISTORIC PRESERVATION COMMISSION

Isiah Leggett
County Executive

William Kirwan
Chairman

Date: July 5, 2018

MEMORANDUM

TO: Diane Schwartz Jones
Department of Permitting Services

FROM: Dan Bruechert
Historic Preservation Section
Maryland-National Capital Park & Planning Commission

SUBJECT: Historic Area Work Permit #839296: Window Replacement

The Montgomery County Historic Preservation Commission (HPC) has reviewed the attached application for a Historic Area Work Permit (HAWP). This application was **Approved** at the June 13, 2018 Historic Preservation Commission meeting.

The HPC staff has reviewed and stamped the attached construction drawings.

THE BUILDING PERMIT FOR THIS PROJECT SHALL BE ISSUED CONDITIONAL UPON ADHERENCE TO THE ABOVE APPROVED HAWP CONDITIONS AND MAY REQUIRE APPROVAL BY DPS OR ANOTHER LOCAL OFFICE BEFORE WORK CAN BEGIN.

Applicant: John Urciolo
Address: 6935 Laurel Ave., Takoma Park

This HAWP approval is subject to the general condition that the applicant will obtain all other applicable Montgomery County or local government agency permits. After the issuance of these permits, the applicant must contact this Historic Preservation Office if any changes to the approved plan are made. Once work is complete the applicant will contact Dan Bruechert at 301.563.3408 or dan.bruechert@montgomeryplanning.org to schedule a follow-up site visit.





DOUBLE-HUNG


GRILLE TYPES

Typical Grille Profiles and Patterns




GRILLE PROFILES

Simulated-Divided-Light Grilles



Roomside Removable Grilles




Grilles-Between-the-Glass




GRILLE PATTERNS

Grilles-Between-the-Glass and Simulated-Divided-Light Grilles



9-Lite Prairie



9-Lite Prairie
Top Sash Only



Top Row




Cross

- 9-Lite Prairie
 - Standard corner lite dimension for Prairie patterns = 2-1/2" VG
 - Available in transoms ≥ 1'3" height and width.

- Cross
 - Minimum DH frame height 35"
 - Horizontal bar will be at 1/2" of the VG height of the top sash.

- Top Row
 - Minimum DH frame height 35"
 - Horizontal bar will be at 1/2" of the VG height of the top sash.

For traditional patterns, see size tables.



VG = Visible Glass





(1) Grilles are available in traditional patterns only.

Lite dimensions noted can vary

For size and pattern availability contact your local Pella sales representative.



UNIT SECTIONS Aluminum-Clad Exterior




Handwritten signature

Scale 3" = 1' 0"
All dimensions are approximate.

Customer Approval Form:

Signature: _____ Date: _____

[Handwritten signature]



Viewed from the Exterior

Quote Number: 10040788

Line Number: 15


Description: ProLine, Double Hung, 40 X 61, Brown

Rough Opening: 40.75" X 61.75"

Quote Qty: 3

Scaling: 1/2" = 1'

These drawings are based on our interpretation of the information provided to us. They are submitted for final approval of the individual** responsible for the project and are not intended to create any warranty or other liability. The user** is responsible for compliance with applicable building codes or other regulations and determining the suitability of the suggestions for the particular application, including the final design of reinforcement, flashing, and sealant systems for all window and door installations.
 ** building owner, architect, contractor, installer and/or consumer

	Quote Name: Final Release - SW	Project Name: Stern, Zoe
	Jobsite Location: Takoma Park, MD	
	Room Location: 201	
	Sales Branch Location: 71700 K. C. Company, Inc.	