Description of Property: Please describe the building and surrounding environment. Include information on significant structures, landscape features, or other significant features of the property:
Residential area, single family home
Description of Work Proposed: Please give an overview of the work to be undertaken:
Installation of 19 solar panels attached flush to existing south and west roof of the house. Roof shingles replacement of the south and west roofs.

Work Item 1: Solar Panels			
Description of Current Condition:	Proposed Work: Installation of 19 black solar panels attached flush to the roof of the house		
Work Item 2: Partial Roof Replacement			
Description of Current Condition:	Proposed Work: Replacement of the south and west roofs of the house with new shingles to match the existing ones.		
Work Item 3:			
Description of Current Condition:	Proposed Work:		

HISTORIC AREA WORK PERMIT CHECKLIST OF APPLICATION REQUIREMENTS

	Required Attachments						
Proposed Work	I. Written Description	2. Site Plan	3. Plans/ Elevations	4. Material Specifications	5. Photographs	6. Tree Survey	7. Property Owner Addresses
New Construction	*	*	*	*	*	*	*
Additions/ Alterations	*	*	*	*	*	*	*
Demolition	*	*	*		*		*
Deck/Porch	*	*	*	*	*	*	*
Fence/Wall	*	*	*	*	*	*	*
Driveway/ Parking Area	*	*		*	*	*	*
Grading/Exc avation/Land scaing	*	*		*	*	*	*
Tree Removal	*	*		*	*	*	*
Siding/ Roof Changes	*	*	*	*	*		*
Window/ Door Changes	*	*	*	*	*		*
Masonry Repair/ Repoint	*	*	*	*	*		*
Signs	*	*	*	*	*		*




ROBERTA VALENTE AND NEIL GOLDSMAN RESIDENCE NEW GRID-INTERACTIVE PHOTOVOLTAIC SYSTEM DC SYSTEM SIZE (8.265 KW)

SYSTEM DETAILS				
DESCRIPTION	NEW GRID-INTERACTIVE PHOTOVOLTAIC SYSTEM WITH NO BATTERY STORAGE			
DC RATING OF SYSTEM	SYSTEM SIZE :8.265 KW DC STC			
AC RATING OF SYSTEM	6.080 KW			
AC OUTPUT CURRENT	31.58 A			
NO. OF MODULES	(19) HD HYUNDAI HIS-T435NF(BK)(435W) SOLAR MODULES			
NO. OF INVERTERS	(19) ENPHASE IQ8MC-72-M-US MICROINVERTERS			
POINT OF INTERCONNECTION	LINE SIDE TAP IN THE MSP			
ARRAY STRINGING	(1) BRANCH OF CIRCUIT 10 MODULES (1) BRANCH OF CIRCUIT 9 MODULES			


SITE DETAILS			
-14°C			
34°C			
30 PSF			
115MPH (ASCE 7-16)			
II			
В			

GOVERNING CODES
INTERNATIONAL BUILDING CODE (IBC) 2021
INTERNATIONAL FIRE CODE (IFC) 2021
INTERNATIONAL RESIDENTIAL CODE (IRC) 2021
NATIONAL ELECTRICAL CODE (NEC) 2017

SHEET INDEX				
SHEET NO.	SHEET NAME			
A - 00	SITE MAP & VICINITY MAP			
A - 01	ROOF PLAN & MODULES			
S - 01	ARRAY LAYOUT			
S - 02	STRUCTURAL ATTACHMENT DETAIL			
E - 01	ELECTRICAL LINE DIAGRAM			
E - 02	WIRING CALCULATIONS			
E - 03	SYSTEM LABELING			
DS - 01	MODULE DATASHEET			
DS - 02	MICROINVERTER DATASHEET			
DS - 03	COMBINER DATASHEET			
DS - 04	RACKING DATASHEET			
DS - 05	ATTACHMENT DATASHEET			







VICINITY MAP



WIND FLOW MAP





BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR COM MHIC 157681

Signature with Se



PERMIT DEVELOPER			
DATE 08/25/2025			
DESIGNER	OVV		
REVIEWER			

SHEET NAME

SITE MAP & VICINITY MAP

SHEET NUMBER

A-00

MODULE TYPE, DIMENSIONS & WEIGHT

NUMBER OF MODULES = 19 MODULES MODULE TYPE = HD HYUNDAI HIS-T435NF(BK)(435W) SOLAR MODULES WEIGHT = 53.57 LBS / 24.3 KG.

MODULE DIMENSIONS = 67.8"X44.6" = 21.00 SF

NUMBER OF INVERTER = 19 MICROINVERTERS
INVERTER TYPE = ENPHASE IQ8MC-72-M-US MICROINVERTERS

DC SYSTEM SIZE: 8.265 KW AC SYSTEM SIZE: 6.080 KW



PROFESSIONAL CERTIFICATION, I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND

LICENSE NUMBER: 56915

EXPIRATION DATE: 12/16/2026

(OUTSIDE HOUSE)


DIES: LOCATI

1. LOCATION OF JUNCTION BOX(ES), AC DISCONNECTS(S), AC COMBINER PANEL(S), AND OTHER ELECTRICAL EQUIPMENT(S) RELEVANT TO PV INSTALLATION SUBJECT TO CHANGE BASED ON SITE CONDITIONS.

2. SETBACKS AT RIDGES CAN BE REDUCED TO 18 INCHES IN COMPLIANCE WITH IBC 2021:
TOTAL PLAN VIEW AREA = 1346.56 SQFT

TOTAL PV AREA = 19(67.8IN)(44.6 IN)/(144 IN^2) = 398.98 SQFT


(398.98 SQFT/1346.56 SQFT)100 = 29.63% TOTAL PV AREA POPULATES 29.63% OF TOTAL PLAN VIEW AREA AND IS WITHIN THE 33% REQUIREMENT.





BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR.COM MHIC 157681

Signature with Sea



PERMIT DEVELOPER

DATE 08/25/2025

DESIGNER OVV

REVIEWER

SHEET NAME

ROOF PLAN & MODULES

SHEET NUMBER
A-01

(N) PV ARRAY ROOF 2 36" SETBACK ROOF 1 (N) CONDUIT RUN **ROOF ACCESS POINT** (N) AC DISCONNECT (FUSED)(INSIDE BASEMENT) (N) COMBINER PANEL **ROOF ACCESS POINT** (OUTSIDE HOUSE) (E) MAIN SERVICE PANEL (N) AC DISCONNECT (INSIDE BASEMENT) (NON-FUSED)(OUTSIDE HOUSE) (E) UTILITY METER

LEGENDS

UM - UTILITY METER

MSP - MAIN SERVICE PANEL

JB - JUNCTION BOX

ACD - AC DISCONNECT

CP - COMBINER PANEL

- FIRE SETBACK
- VENT, ATTIC FAN

(ROOF OBSTRUCTION)- CONDUIT

STRING

ROOF DESCRIPTION:

(ROOF #1)

MODULES - 10 ROOF TILT - 45° ROOF AZIMUTH - 159° RAFTER SIZE - 2"X6"@24" O.C.

11'-6"

(ROOF #2)

MODULES - 9 ROOF TILT - 24° ROOF AZIMUTH - 249° RAFTER SIZE - 2"X6"@24" O.C.



40'-6"

40'-6" -

ROOF #1

PROFESSIONAL CERTIFICATION, I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND

LICENSE NUMBER: 56915

_9-


Н


EXPIRATION DATE: 12/16/2026



BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR.COM MHIC 157681

Signature with Sea





LEGENDS



- FIRE SETBACK



- VENT, ATTIC FAN (ROOF OBSTRUCTION)



- RAFTERS / TRUSSES

SHEET NUMBER S-01

PERMIT DEVELOPER

SHEET NAME

ARRAY

LAYOUT

DATE

DESIGNER


REVIEWER


08/25/2025

OVV

PHOTOVOLTAIC MODULE GENERAL NOTES:

- 1. APPLICABLE CODE: INTERNATIONAL RESIDENTIAL CODE 2021
 MINIMUM DESIGN LOADS FOR BUILDING AND OTHER STRUCTURES
- 2. BOLT DIAMETER AND EMBEDMENT LENGTHS ARE DESIGNED PER NDS REQUIREMENTS. ALL BOLT CAPACITIES ARE BASED ON A WOOD ROOF RAFTER AS EMBEDMENT MATERIAL.
- 3. ALL WIND DESIGN CRITERIA AND PARAMETERS ARE FOR HIP AND GABLE RESIDENTIAL ROOFS, CONSIDERING FROM A 7° TO A MAXIMUM 45° (2/12 TO A MAXIMUM 9/12 PITCH) ROOF IN SCHEDULE. ALL RESIDENTIAL ROOFS SHALL NOT EXCEED 30'-0" MEAN ROOF HEIGHT.
- 4. ROOF SEALANTS SHALL CONFORM TO ASTM C920 AND ASTM 6511.
- 5. THIS SHEET REFLECTS STRUCTURAL CONNECTIONS ONLY. REFER TO MANUFACTURERS' MANUAL FOR ALL ARCHITECTURAL, MECHANICAL, ELECTRICAL, AND SOLAR SPECS.
- 6. ALL ALUMINUM COMPONENTS SHALL BE ANODIZED ALUMINUM 6105-T5 UNLESS OTHERWISE NOTED.
- 7. LAG BOLTS SHALL BE ASTM A276 STAINLESS STEEL UNLESS OTHERWISE NOTED.
- ALL RAILING AND MODULES SHALL BE INSTALLED PER MANUFACTURERS' INSTRUCTIONS.
- 9. I CERTIFY THAT THE INSTALLATION OF THE MODULES IS IN COMPLIANCE WITH INTERNATIONAL RESIDENTIAL CODE 2021 AND INTERNATIONAL BUILDING CODE 2021. BUILDING STRUCTURE WILL SAFELY ACCOMMODATE CALCULATED WIND LATERAL AND UPLIFT FORCES, AND EQUIPMENT DEAD LOADS.





STRUCTURAL ATTACHMENT DETAILS FOR ASPHALT SHINGLE



BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR.COM MHIC 157681

Signature with 9

7101 POPLAR AVE, TAKOMA PARK, MD 20912, USA

П				
	PERMIT DEVELOPER			
	DATE	08/25/2025		
	DESIGNER	OVV		
1	REVIEWER			

SHEET NAME
STRUCTURAL
ATTACHMENT
DETAILS

SHEET NUMBER

S-02

MODULE SPECIFICATION		
MANUFACTURER	HD HYUNDAI SOLAR	
MODEL NO	HIS-T435NF(BK)(435W)	
OPEN CIRCUIT VOLTAGE (Voc)	38.90V	
SHORT CIRCUIT CURRENT(Isc)	14.19A	
RATED VOLTAGE (Vmpp)	32.08V	
RATED CURRENT (Impp)	13.56A	

MICRO INVERTER SPECIFICATION			
MANUFACTURER	ENPHASE		
MODEL NO.	IQ8MC-72-M-US		
MAX. OUTPUT POWER	320W		
MAX. AC OUTPUT VOLTAGE	240V		
AC OUTPUT CURRENT	1.33A		

ARRAY DETAILS		
DC SYSTEM SIZE	8.265 KW	
AC SYSTEM SIZE	6.080 KW	
TOTAL NO. OF MODULES	19	
NO. OF MODULE PER STRING	1@10,1@9	
NO. OF STRING	2	

- 1. SUBJECT PV SYSTEMS HAS BEEN DESIGNED TO MEET THE REQUIREMENTS OF THE NEC 2017, NFPA 70. INCLUDING MAXIMUM NUMBER OF MODULE STRINGS, MAXIMUM NUMBER OF MODULES PER STRING, MAXIMUM OUTPUT, MODULE MANUFACTURER AND MODEL NUMBER, INVERTER MANUFACTURER AND MODEL NUMBER, AS
- 2. PROVIDE TAP BOX IN COMPLIANCE WITH 312.8 IF PANEL GUTTER SPACE IS INADEQUATE.


BEE HAPPYSOLAR.COM MHIC 157681

NOTE: CONDUIT RUN AS PER NEC 2017

NOTE: EXTERIOR AC DISCONNECT IS LOCKABLE, TAGGABLE, VISIBLE BREAK AND ACCESSIBLE 24/7

SMART INVERTER COMPLIANCE WITH IEEE-1547-2018 AND CERTIFIED TO UL-1741-SB

CONDUIT SCHEDULE				
SR. NO.	DESCRIPTION	CONDUIT SIZE		
A	ENPHASE Q-CABLES, (1)#6 BARE CU (G)	N/A FREE AIR		
1	(2) #10 AWG THWN-2 CU (L1), (2) #10 AWG THWN-2 CU (L2), (1)#8 AWG THWN-2 CU (G)	IN 3/4" EMT CONDUIT		
2	(3) #6 AWG THWN-2 CU (L1,L2,N) , (1) #8 AWG THWN-2 CU (G)	IN 3/4" EMT CONDUIT		
3	(3) #6 AWG THWN-2 CU (L1,L2,N), (1) #8 AWG THWN-2 CU (G)	IN 3/4" EMT CONDUIT		







PERMIT DEVELOPER					
DATE	08/25/2025				
DESIGNER	OVV				
REVIEWER					

SHEET NAME

ELECTRICAL LINE DIAGRAM

SHEET NUMBER

E-01

ELECTRICAL CALCULATIONS:

CURRENT CARRYING CONDUCTOR

(A) <u>BEFORE IQ COMBINER PANEL</u>
AMBIENT TEMPERATURE - = 34°C ...NEC 310.15(B)(2)
TEMPERATURE DERATE FACTOR - 0.96 ...NEC 310.15(B)(1)(1)
GROUPING FACTOR -0.8...NEC 310.15(C)(1)

CONDUCTOR AMPACITY

- = (INV O/P CURRENT) x 1.25 / A.T.F / G.F ...NEC 690.8(B)
- = [(10x 1.33) x 1.25] / 0.96 / 0.8
- = 21.64 A

SELECTED CONDUCTOR - #10 THWN-2 ... NEC 310.16

(B) <u>AFTER IQ COMBINER PANEL</u> TEMPERATURE DERATE FACTOR - 0.96 GROUPING FACTOR - 1

CONDUCTOR AMPACITY

- = (TOTAL INV O/P CURRENT) x 1.25 / 0.96 / 1 ... NEC 690.8(B)
- = [(19x 1.33) x 1.25] / 0.96 / 1
- = 32.90 A

SELECTED CONDUCTOR - #6 THWN-2 ... NEC 310.16

- 2. PV OVER CURRENT PROTECTION ..NEC 690.9(B)
- = TOTAL INVERTER O/P CURRENT x 1.25
- = (19 x 1.33) x 1.25 = 31.59 A SELECTED OCPD = 35 A

GENERAL ELECTRICAL NOTES:

- THE DC AND AC CONNECTORS OF THE ENPHASE IQ8MC-72-M-US MICROINVERTERS ARE LISTED TO MEET REQUIREMENTS AS A DISCONNECT MEANS AS ALLOWED BY NEC 690.15(A).
- 2. MICROINVERTER BRANCH CIRCUIT CONDUCTORS ARE MANUFACTURED ENPHASE Q CABLES LISTED FOR USE IN 20A OR LESS CIRCUITS OF ENPHASE IQ MICROINVERTERS. THEY ARE ROHS, OIL RESISTANT, AND UV RESISTANT. THEY CONTAIN AWG CONDUCTORS OF TYPE THHN/THWN-2 DRY/WET AND CERTIFIED TO UL3003 AND UL 9703. THE CABLE'S DOUBLE INSULATED RATING REQUIRES NO NEUTRAL OR GROUNDED CONDUCTOR.
- 3. ALL METAL ENCLOSURES, RACEWAYS, CABLES AND EXPOSED NONCURRENT-CARRYING METAL PARTS OF EQUIPMENT SHALL BE GROUNDED TO EARTH AS REQUIRED BY NEC 250.4(B) AND PART III OF NEC ARTICLE 250 AND EQUIPMENT GROUNDING CONDUCTORS SHALL BE SIZED ACCORDING TO NEC 690.45. THE GROUNDING ELECTRODE SYSTEM SHALL ADHERE TO 690.47(A)
- 4. PV SYSTEM DISCONNECT SHALL BE READILY ACCESSIBLE.
- 5. POINT-OF-CONNECTION SHALL BE MADE IN COMPLIANCE WITH NEC 705.12
- 6. UTILITY HAS 24-HR UNRESTRICTED ACCESS TO ALL PHOTOVOLTAIC SYSTEM COMPONENTS LOCATED AT THE SERVICE ENTRANCE.
- 7. MODULES CONFORM TO AND ARE LISTED UNDER UL 1703. OPTIMIZERS CONFORM TO AND ARE LISTED UNDER UL 1741.
- 8. CONDUCTORS EXPOSED TO SUNLIGHT SHALL BE LISTED AS SUNLIGHT RESISTANT PER NEC ARTICLE 300.6(C)(1) AND ARTICLE 310.10 (D).
- 9. CONDUCTORS EXPOSED TO WET LOCATIONS SHALL BE SUITABLE FOR USE IN WET LOCATIONS PER NEC ARTICLE 310.10 (C).

GROUNDING NOTES:

PV MODULE AND RACKING GROUNDING AS PER APPROVED INSTALLATION PRACTICE AND IN LINE WITH MANUFACTURE'S GUIDELINES.



BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR.COM MHIC 157681

Signature with Sea



PERMIT DEVELOPER				
DATE	08/25/2025			
DESIGNER	ovv			
REVIEWER				

SHEET NAME WIRING

CALCULATIONS

SHEET NUMBER

E-02

SOLAR AC DISCONNECT & INVERTER LABELS

WARNING

DO NOT TOUCH TERMINALS
TERMINALS ON BOTH LINE AND LOAD
SIDES MAY BE ENERGIZED IN THE OPEN


WARNING

AC VOLTAGE = 240VMAX FUSE: 35 A MAX CURRENT: 31.58 A

AC COMBINER PANEL LABELS

SOLAR PV SYSTEM EQUIPPED WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN SWITCH TO THE "OFF" POSITION TO SHUTDOWN PV SYSTEM AND REDUCE SHOCK HAZARD IN ARRAY



CONDUIT LABELS

CAUTION

PHOTOVOLTAIC AC SOURCE

SERVICE PANEL LABEL

WARNING

THIS SERVICE IS ALSO SERVED BY A PV SYSTEM WITH RAPID SHUTDOWN. INVERTERS LOCATED ON ROOF AUTO DE-ENERGISE WHEN SOLAR SERVICE MAIN IS THE DC CONDUCTORS OF THE PV SYSTEM ARE UNGROUNDED AND MAY BE ENEGIZED. IF BACKFEED BREAKER PRESENT DO NOT RELOCATE THIS OVERCURRENT DEVICE.

CAUTION

DO NOT DISCONNECT UNDER LOAD

NO USER SERVICEABLE PARTS INSIDE NTACT AUTHORIZED SERVICE PROVIDE FOR ASSISTANCE

ELECTRIC SHOCK HAZARD THE DC CONDUCTORS OF THIS PHOTOVOLTAIC SYSTEM ARE ROUNDED AND MAY BE ENERGIZE

PHOTOVOLTAIC SYSTEM **EQUIPPED WITH RAPID SHUTDOWN**

UTILITY METER

WARNING



↑ DUAL POWER SOURCE ↑

NOTICE

THIS SYSTEM IS EQUIPPED WITH RAPID SHUTDOWN ROOFTOP INVERTERS WILL DE-ENERGISE AT SERVICE PANEL OUTAGE

NOTICE

AC COMBINER AND DATA AQUISITION. DO NOT ADD LOADS. DO NOT TOUCH TERMINALS. LINE AND LOAD SIDE MAY BE ENERGIZED IN OPEN POSITION.

LABEL

CAUTION


SOLAR CIRCUIT

EMERGENCY CONTACT BEE HAPPY SOLAR 888-270-4030

WARNING /!\



POWER TO THIS BUILDING IS ALSO SUPPLIED FROM THE FOLLOWING SOURCES WITH DISCONNECTS LOCATED AS SHOWN



SITE ADDRESS: 7101 POPLAR AVE, TAKOMA PARK, MD 20912, USA



1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR.COM MHIC 157681

Signature with Seal

7101 POPLAR AVE, TAKOMA PARK, MD 20912, USA

PERMIT DEVELOPER 08/25/2025 DATE DESIGNER

SHEET NAME

REVIEWER

SYSTEM LABELING

SHEET NUMBER

E-03



eng.hd-hyundales.co.kr


PRELIMINARY

HD HYUNDAI SOLAR MODULE

NF(BK) Series

Premium N-Type TOPCon Module

HiS-T425NF(BK) | HiS-T430NF(BK) | HiS-T435NF(BK)





High Efficiency







Long-Term



For Residential (Full Black Design)


HD Hyundail's Warranty Provisions



25-Year Product Warranty Materials and workmanship



30-Year Performance Warranty · First: year degradation: 1% -Linear warranty after initial year: with 0.4% pannual degradation, 87,4% is guaranteed up to 30 years



Certification



- · UL 61215 / UL 61730 / IRC 61215 / IRC 61730 Certified
- ISO 9001 : Guality management systems ISO 14001 : Environmental management systems
- ISO 45001 : Competiera hoalth and rafety management ryscens

Electrical Characteristics

HiS-TxxxNF(BK)		HiS-T42	5NF(BK)	HiS-T430NF(BK)		HiS-T435NF(BK)	
Item	Unit		BNPF		BNPI		BNPI
Nominal output (Pmax)	W	425	470	430	475	435	480
Open circuit voltage (Voc)	V	38.50	38.54	38.70	38.85	38,90	39.05
Short circuit current (Isc)	Α	13.95	15.46	14.11	15.63	14.19	15.72
Voltage at Pmax (Vmpp)	V	31.76	31,98	31.85	32,03	32,08	32.21
Current at Pmax (Impp)	Α	13.38	14.72	13.50	14.86	13.56	14.95
Module efficiency	%	21.76		22.02		22.28	
Power Class Sorting W				0 ~	+5		
Temperature coefficient of Pmax	%/K	-0.2			290		
Temperature coefficient of Voc	%/K			-0.250			
Temperature coefficient of Isc	%/K	0.043			143		
Bifaciality	%			80	bh5		

*STC: Irradiance 1,000 W/m², belicemperature 25°C, AM=1.5 / Measurement uncertainty for Pmax x 3%; loc; Vbc x5%.
**The electrical properties of 6 VPI or a measured under the irradiance corresponding to 1000 W/m² on the module front and 135 W/m² on the module rear.

Additional Power Gain from rear side						
Pmpp gain	Pmpp [W]	Vmpp [V]	Impp [A]	Voc [V]	Isc [A]	
5%	452	31.88	14/18	38.70	14.82	
15%	495	31.85	15.53	38.70	16.23	
25%	538	31.85	16.80	38.70	17.64	

"Bectrical characteristics with different rear power gain (reference to 430.9)

Mechanical Characteristics

Dimensions	1,722mm (L) x 1,134mm (W) x 30mm (H) (67,6in x 44,6in x 1,2in)
Weight	24.3 kg (53.57 lbs)
Solar Cells	N-Typa TOPCon, 108 (6x18) monocrystalline 1658 half-cut bifadal cells
Output Cables	Cable : (+)1,200mm(47.2in), (-)1,200mm(47.2in) / Customized length available Connector : Stäubli MC4 genuine Connector
Junction Box	3-part, 3 bypass diodes, IP68 rated
Construction	Front : 2,0mm(0.06m) semi-tempered solar glass with high transmittance and anti-reflective costing Rear : 2,0mm(0.08in) semi-tempered solar glass
Frame	Anceitaed aluminum alley

Shipping Configurations


Container Size (HC)	40'	Modules Per Pallet (pcs)	36
Pallets Per Container	26	Modules Per Container (pcs)	936

Installation Safety Guide


- · Only qualified personnel should install or perform maintenance.
- Be aware of dangerous high DC voitage.
- · Do not hencle or install modules when they are wet,

Nominal Module Operation Temperature	41°C±2°C
Operating Temperature	-40°C~+85°C
Maximum System Voltage	DC 1,500 V
Maximum Reverse Current	30A
Maximum Test Load	Front:5,400Pa Rear:2,400Pa
Fire Performance	Type 29

Module Diagram (unit: mm)



I-V Curves (HIS-T430NF(BK))



voltage [V]
30 40
Voltage [∨]

Sales & Marketing

HD Hyundai Energy Solutions reserves the right to update or modify the specifications and features listed in this datasheet without prior notice. Always check the latest version of the datasheet for accurate information. Before using the product, please refer to the installation and Operation Manual and Warranty. We retain the right of first interpretation.



BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR.COM MHIC 157681

7101 POPLAR AVE, TAKOMA PARK, MD 20912, USA

PERMIT DEVELOPER 08/25/2025 DESIGNER OVV REVIEWER

SHEET NAME

MODULE DATASHEET

SHEET NUMBER



BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR.COM MHIC 157681

Signature with Sea

7101 POPLAR AVE, TAKOMA PARK, MD 20912, USA

PERMIT DEVELOPER

DATE 08/25/2025

DESIGNER OVV

REVIEWER

SHEET NAME

MICROINVERTER DATASHEET

SHEET NUMBER

DS-02

⊖ ENPHASE.



IQ8MC Microinverter

Gur namest füß Series Miloroinvertors are the industry's first microgrid-forming', seftwaredefinised microinverties with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semboundator-based microinverter is as a proprietary application-opeoific invegrated circuit (ASIC), which enables the microinverter to operate in grid-field or orth-grid modes. This chip is built in advanced 55-mm technology with high-speed digifall ologic and heas super-later response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Past of the Englisese Energy Systems, IOS Sorkee Microimvorters integrate with the IO Battery, IO Gateway, and the III Battery, IO Gateway, and the Issue App inonitioning and analysis software.



Connect PV modules guickly and easily to the IOB Series Microlinverters that have integrated MC4 connectors.



IOS Series Microlines tens radefine reliability standards with more than one million cumulative hours of posser-on testing, enabling an industry-feeding limited warranty of up to 25 years.



IGS Series Microinverters are UL Listed as PV rapid shutdown equipment and conforms with various regulations when installed according to the manufacturer's instructions.

"March UL TPC on the beninderly with IC Steben Copyright 2 o

DISSIN Symbols Employ All rights reserved. Sephano, the elant ISSI legac. (It, and existin either marks listed at littless and consequences of the consequence of the consequence of Rephase Review, inc. inthe ULL and other sevention Catalogue of the property.

Easy to install

 Lightweight and compact with plug-and-play connectors

DATA SHEET

- Power line communication (PLC) between components
- Faster installation with simple two-wire

High productivity and reliability

- Produces power even when the grid is down*
 More than one million cumulative hours of
- Class II double-insulated enclosure
- Optimized for the latest high-powered PV modules

rogrid-forming

- Complies with the latest advanced grid support
- Remote automatic updates for the latest grid requirements
 Configurable to support a wide range of grid
- profiles

 Meets CA Rule 21 (UL 1741-SA) and IEEE 1547:2018 (UL 1741-SB)

NOTE

KIB Microinverters cannot be mixed together with previous generations of Enghase microinverters (ICF Series, ICE Series, and so on) in the same

IQ Microinverters ship with default settings that
most North America IEEE IB-47 interconnection
standard requirements. Region-specific
adjustments may be requested by an Authority
Having Juried often (AHJ) or utility representative.
An IQ Gateway is required to make these changes

ION HTC-HC44081-09049-LG-TR-LIE-2524-02-09

IQ8MC Microinverter

INPUT DATA (DC)	UNITS	709	C-72-M-US	
Commonly used module pairings 1	W	26	30-460	
Module compatibility –		To meet competibility, PV modules must be within the following max, input DC voltage and max, module in Module competibility can be checked at		

Revision history

REVISION DATE

DSH-00049-4.0 February 2024 DSH-00049-3.0 October 2023

DSH-00049-2.0 September 2023

DSH-00049-1.0 May 2023

DESCRIPTION

Updated module compatibility information.

Preliminary release.

Added information about IEEE 1547 interconnection standard requirements. Included NEC 2023 specification in the "Compilance" section.

iO8803-604-081-06048-4.0-EN4IS-2521-02-08

8 2004 Subbas Frengs, All rights reserved. Engineers free a and 00 lagues 10, and sentin other marks listed at https://documencestrade.na/stansacrambhilitess and transfer of Rephress Freegy free, forthe U.C. and other reput

i08HD-MC4-D8H-06048-4.0-D8-H2-2524-02-09

Data Sheet Enphase Networking

Enphase IQ Combiner 4/4C

X-IQ-AM1-240-4 X-IQ-AM1-240-4C



The Enphase IQ Combiner 4/4C with Enphase IQ Gateway and integrated LTE-M1 cell modern (included only with IQ Combiner 4C) consolidates interconnection equipment into a single enclosure and streamlines IQ microinverters and storage installations by providing a consistent, pre-wired solution for residential applications. It offers up to four 2-pole input circuits and Eaton BR series busbar assembly.

Smart

- Includes IQ Gateway for communication and control
- Includes Enphase Mobile Connect cellular modern (GELLMODEM-M1-06-SP-05), included only with IQ Combiner 4C
- Includes solar shield to match Enphase IQ Battery aesthetics and deflect heat
- Flexible networking supports Wi-Fi,
 Ethernet, or cellular
- · Optional AC receptacle available for PLC bridge
- Provides production metering and consumption monitoring

Simple

- Centered mounting brackets support single stud mounting
- Supports bottom, back and side conduit entry
- Up to four 2-pole branch circuits for 240 VAC plug-in breakers (not included)
- · 80A total PV or storage branch circuits

Reliable

- Durable NRTL-certified NEMA type 3R enclosure
- Five-year limited warranty
- Two years labor reimbursement program coverage included for both the IQ Combiner SKU's
- UL listed



Enphase IQ Combiner 4/4C

MODEL NUMBER	
IQ Combiner 4 (X-IQ-AM1-240-4)	IQ Combiner 4 with Enphase IQ Gateway printed circuit board for integrated revenue grade PV production metering (ANS C12.20 +/-0.5%) and consumption monitoring (+/-2.5%). Includes a silver solar shield to match the IQ Battery system and IQ System Controller 2 and to deflect heat.
IQ Combiner 4C (X-IQ-AM1-240-4C)	IQ Combiner 4C with Enghase IQ Gateway princed ofrcuit board for integrated revenue grade PV production metering (ANBI 012.20 4-9.0.5%) and consumption intentioring (4-9.2.5%), Includes Enghase Mobile Connect cellular modern (CRELIMODEM-M1-06-SP-05), a plug-and-play industrial-grade cell modern for systems up to modern for systems up to make the confirmation of the US Virgin Islands, where there is adequate cellular service in the installation area.) Includes a silver solar shield to match the IQ Battery and IQ System Controller and to deflect heat
ACCESSORIES AND REPLACEMENT PARTS	(not included, order separately)
Ensemble Communications Kit COMMS-CELLMODEM-M1-06 CELLMODEM-M1-06-SP-05 CELLMODEM-M1-06-AT-05	- Includes COMMS-KIT-01 and CELLMODEM-M1-06-SP-05 with 5-year Sprint data plan for Ensemble sites - 4G based LTE-M1 cellular modem with 5-year Sprint data plan - 4G based LTE-M1 cellular modem with 5-year AT&T data plan
Circuit Brackers BRK-10A-2-240V BRK-15A-2-240V BRK-26A-2-240V BRK-15A-2P-240V-8 BRK-20A-2P-240V-8	Supports Eaten BR210, BR215, BR220, BR230, BR240, BR250, and BR260 circuit breakers. Circuit breaker, 2 pole, 16A, Eaten BR210 Circuit breaker, 2 pole, 15A, Eaten BR215 Circuit breaker, 2 pole, 20A, Eaten BR220 Circuit breaker, 2 pole, 15A, Eaten BR220 Circuit breaker, 2 pole, 25A, Eaten BR2158 with hold down ldt support Circuit breaker, 2 pole, 26A, Eaten BR2208 with hold down ldt support
EPLC-01	Power line carrier (communication bridge pair), quantity - one pair
XA-SOLARSHIELD-ES	Replacement solar shield for IQ Combiner 4/40
XA-PLUG-120-3	Accessory receptacle for Power Line Carrier in IQ Combiner 4/4C (required for EPLC-01)
XA-ENV-PCBA-3	Replacement IQ Gateway printed circuit board (PCB) for Combiner 4/4C
X-IQ-NA-HD-125A	Hold down kit for Eaton circuit breaker with screws.
ELECTRICAL SPECIFICATIONS	
Rating	Continuous duty
System voltage	120/240 VAC, 60 Hz
Eaton BR series busbar rating	125 A
Max, continuous current rating	65 A
Max. continuous current rating (input from PV/storage)	64 A
Max. fuse/circuit rating (output)	90 A
Branch circuits (solar and/or storage)	Up to four 2-pole Eaton BR series Distributed Generation (DG) breakers only (not included)
Max, total branch circuit breaker rating (input)	80A of distributed generation / 95A with IC Gateway breaker included
Envoy breaker	10A or 15A rating GE/Siemens/Eaton included
Production metering CT	200 A solid core pre-installed and wired to IQ Gataway
Consumption monitoring CT (CT-200-SPLIT)	A pair of 200 A split core current transformers
MECHANICAL DATA	The state of the s
Dimensions (WxHxD)	37.5 x 49.5 x 16.8 cm (14.75" x 19.5" x 6.63"). Height is 21.06" (53.5 cm) with mounting brackets.
Weight	7.5 kg (16.5/ba)
•	-40° C to +46° C (-40° to 115° F)
Ambient temperature range	
Cooling	Natural convection, plus heat shield
Enclosure environmental rating	Outdoor, NRTL-certified, NEMA type 3R, polycarbonate construction
Wire aizes	 2.0 A to 50 A breaker inputs: 14 to 4 AWG copper conductors 60 A breaker horizon Input: 4 to 1/h AWG copper conductors Main fug combined output: 10 to 2/0 AWG copper conductors Neutral and ground: 14 to 1/0 copper conductors Always follow local code requirements for conductor sizing.
Altitude	To 2000 meters (6,560 feet)
INTERNET CONNECTION OPTIONS	
Integrated Wi-Fi	802.11b/g/n
Cellular	CELLMODEM-MI-06-SP-05, CELLMODEM-MI-06-AT-05 (4G based LTE-M1 cellular modem). Note that an Enphase Mobile Connect cellular modem is required for all Ensemble Installations.
Ethernet	Optional, 802.3, Cat5E (or Cat 6) UTP Ethernet cable (not included)
COMPLIANCE	
0 1 10 0 1	UL 1741, CAN/CSA C22.2 No. 107.1, 47 CFR, Part 15, Class B, ICES 003
Compliance, IQ Combiner	Production metering: ANSI C12.20 accuracy class 0.5 (PV production) Consumption metering: accuracy class 2.5



® 2022 Enghase Energy, All rights reserved. Enghase, the Enghase loge, IQ Combiner 4/4C, and other names are trademarks of Enghase Energy, Inc. Data subject to change. 02-14-2032.



BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR.COM MHIC 157681

Signature with Sea

7101 POPLAR AVE, TAKOMA PARK, MD 20912, USA

PERMIT DEVELOPER				
DATE	08/25/2025			
DESIGNER	OVV			
REVIEWER				

SHEET NAME

⊖ ENPHASE.

COMBINER DATASHEET

SHEET NUMBER




XR Rail Family

Solar Is Not Always Sunny

Over their lifetime, solar panels experience countless extreme weather events. Not just the worst storms in years, but the worst storms in 40 years. High winds capable of ripping panels from a roof, and snowfalls weighing enough to buckle a panel frame.

XR Rails are the structural backbone preventing these results. They resist uplift, protect against buckling and safely and efficiently transfer loads into the building structure. Their superior spanning capability requires fewer roof attachments, reducing the number of roof penetrations and the amount of installation time.



Force-Stabilizing Curve

Sloped roofs generate both vertical and lateral forces on mounting rails which can cause them to bend and twist. The curved shape of XR Rails is specially designed to increase strength in both directions while resisting the twisting. This unique feature ensures greater security during extreme weather and a longer system lifetime.

Compatible with Flat & Pitched Roofs



XR Rails are compatible with FlashFoot and other pitched roof



IronRidge offers a range of tilt leg options for flat roof mounting applications.

Corrosion-Resistant Materials

All XR Rails are made of marine-grade aluminum alloy, then protected with an anodized finish. Anodizing prevents surface and structural corrosion, while also providing a more attractive appearance.



XR Rail Family

The XR Rail Family offers the strength of a curved rail in three targeted sizes. Each size supports specific design loads, while minimizing material costs. Depending on your location, there is an XR Rail to match.



XR10

XR10 is a sleek, low-profile mounting rail, designed for regions with light or no snow. It achieves 6 foot spans, while remaining light and economical.

- · 6' spanning capability
- · Moderate load capability
- Clear anodized finish · Internal splices available



XR100

XR100 is the ultimate residential mounting rail. It supports a range of wind and snow conditions, while also maximizing spans up to 8 feet

- · 8' spanning capability
- · Heavy load capability · Clear & black anodized finish
- internal splices available



XR1000

XR1000 is a heavyweight among solar mounting rails. It's built to handle extreme climates and spans 12 feet or more for commercial applications.

- · 12' spanning capability
- Extreme load capability
- Clear anodized finish
- · Internal splices available

Rail Selection

The following table was prepared in compliance with applicable engineering codes and standards. Values are based on the following criteria: ASCE 7-10, Roof Zone 1, Exposure B, Roof Slope of 7 to 27 degrees and Mean Building Height of 30 ft. Visit IronRidge.com for detailed span tables and certifications.

Load		Rail Span						
Snow (PSF)	Wind (MPH)	4'	5' 4"	6'	8'	10'	12'	
None	100							
	120							
	140	XR10		XR100		XR1000		
	160							
10-20	100							
	120							
	140							
	160							
30	100							
	160							
40	100							
	160							
50-70	160							
80-90	160							



BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 MHIC 157681

Signature with Seal

7101 POPLAR AVE, TAKOMA PARK, MD 20912, USA

PERMIT DEVELOPER					
DATE	08/25/2025				
DESIGNER	ovv				
REVIEWER					

SHEET NAME

RACKING DATASHEET

SHEET NUMBER

QuickMount® HUG



The Respect Your Roof Deserves

When integrating with a home, solar attachments must be dependable for the lifetime of the rooftop. Due to recent innovations, many asphalt shingles have bonded courses. A mount that protects without the need to pry shingles can really speed things up.





Triple Rated & Certified to Respect the Roof" UL 2703, 441 (27) TAS 100(A)-95





Rafter & Deck Mounting Options

Mount HUG to the roof rafters, the roof deck, or both with our custom-engineered RD (rafter-or-deck) Structural Screw. The RD Structural Screw anchors HUG to the roof with an EPDM sealing washer, completing the stack of waterproofing barriers. See backside for more installation information

Adaptive, Rafter-Friendly Installation







Trusted Strength & Less Hassle



Structural capacities of HUG™ were reviewed in many load directions, with racking rail running cross-slope or up-slope in relation to roof pitch.

For further details, see the HUG certification letters for attaching to rafters and decking.

IronRidge designed the HUG, in combination with the RD Structural Screw to streamline installs, which means the following:

- · No prying shingles
- · No roof nail interference
- · No pilot holes necessary
- · No sealant (in most cases)
- · No butyl shims needed

Attachment Loading



The rafter-mounted HUG has been tested and rated to support 1004 (lbs) of uplift and 368 (lbs) of lateral load.

Structural Design

Parts are designed and certified for compliance with the International Building Code & ASCE/SEI-7.

Water Seal Ratings



HUG passed both the UL 441 Section 27 "Rain Test" and TAS 100(A)-95 "Wind Driven Rain Test" by Intertek.

UL 2703 System



Systems conform to UL 2703 mechanical and bonding requirements. See Flush Mount Manual for more info.

© 2023 IronRidge, Inc. All rights reserved. Visit www.ir-patents.com for patent information. Version 1.02





BEE HAPPY SOLAR 1125 WEST ST, SUITE 432 ANNAPOLIS, MD 21401 TEL: 888-270-4030 BEE HAPPYSOLAR.COM MHIC 157681

Signature with Seal

POPLAR AVE, A PARK, MD 20912, USA 7101 F TAKOMA I

PERMIT DEVELOPER DATE 08/25/2025 DESIGNER OVV

SHEET NAME

REVIEWER

ATTACHMENT DATASHEET

SHEET NUMBER




[EXTERNAL EMAIL] Exercise caution when opening attachments, clicking links, or responding.

Hi Devon,

As per your request, please find the attached heat map for the current proposed system.





The estimated system production with the current layout is 10,745 kwh a year.

If we move the panels to the back roof, the system production will be 8,759 kwh a year, **which is an 18% drop in production.**

The estimated amount of energy required to make this project financially feasible is 10,745 kwh a year.

Please also note that the front roof is not visible from the sidewalk or the sidewalk across. Please see the attached pictures. Also, the house is quite tall, making it almost impossible to see the solar from any angle.

Please let me know if you have any questions or require any additional information.

Best Regards,

Elena Zenke Founder/Solar Guru



On Thu, Sep 11, 2025 at 1:39 PM Murtha, Devon < <u>Devon.Murtha@montgomeryplanning.org</u>> wrote:

Hello Elena,

I hope this email finds you well!

I am reviewing your Historic Area Work permit application for solar panel installation on the roof of 7101 Poplar Avenue. I understand that recent federal legislation has impacted financing for these projects, and that there is a rush to get these projects underway before the end of the year. Considering this, I am reaching out to all applicants in advance of the HPC deadline to ensure that applications are complete and do not get bumped to a later agenda due to a lack of documentation.

In reviewing your application, I see that you are proposing installing some panels on the front-facing main roof. The HPC policy discourages this placement - see the full policy here: https://montgomeryplanning.org/wp-content/uploads/2021/12/Solar-Panel-Interactive.pdf. However, the HPC can consider approval of panels on front roof slopes if the applicant provides evidence that this is the only feasible location for the panels. Please submit your justification, including

- A heat map
- The breakdown of the estimated energy output per panel

• The estimated amount of energy required to make the project practically and financially feasible.

All materials for the October 8th HPC meeting are **due September 17**th **at 5pm**. Please let me know in advance if you have any questions or need an example of a justification that we have accepted in the past.

Thanks,

Devon



Devon Murtha

Cultural Resources Planner II

she/her

Montgomery County Planning Department

2425 Reedie Drive, 3rd Floor, Wheaton, MD 20902

devon.murtha@montgomeryplanning.org

o: 301.495.1328












Annual irradiance



Summary

Array ID	Panel count	Azimuth	Pitch	Annual TOF	Annual solar access	Annual TSRF
1	9	69°	29°	74%	72%	53%
2	10	159°	50°	96%	97%	94%
			Weighted avera	ige by panel count:	85.2%	74.6%

The estimated amount of energy required to make this project financially feasible is 10,745 kwh a year.

Please also note that the front roof is not visible from the sidewalk or the sidewalk across. Please see the attached pictures. Also, the house is quite tall, making it almost impossible to see the solar from any angle.

Please let me know if you have any questions or require any additional information.

Best Regards,

Elena Zenke Founder/Solar Guru



Devon,

As a follow up on the above questions, and to compare the front vs the back: The 9 panels (3.92 KW) on the front will produce 4,585 kwh The 9 panels(3.92 KW) on the back will produce 2,599 kwh The comparison between just those two arrays is very significant. Hope this helps.

Best Regards,

Elena Zenke Founder/Solar Guru

1) The estimated electricity consumption for the past 12 months is 10,702 kwh.
2) We can only fit one additional panel on the rear slope, the estimated total system production will be 9,243 KWh a year which is under the required coverage. Adding one panel will also increase the system cost by \$1,546.00. Using the back roof will not be feasible or financially attainable for the homeowners.
Best Regards,
Elena Zenke